



## **LEAD IN POTABLE WATER SCREENING REPORT**

---

**INVESTIGATION FOR:** David Robertin  
Dobbs Ferry Union Free School District  
505 Broadway  
Dobbs Ferry, NY 10522

**SITE INVESTIGATED:** Springhurst Elementary School  
175 Walgrove Avenue  
Dobbs Ferry, NY 10522

**ASSESSMENT BY:** Dave Ekstrand  
Omega Environmental Services, Inc.  
280 Huyler Street  
South Hackensack, NJ 07606

**INVESTIGATION  
CONDUCTED:** 9/24/16

**DATE OF REPORT:** 11/1/16

(Omega Project # 16-1300)

## **TABLE OF CONTENTS**

### **EXECUTIVE SUMMARY/PROJECT OVERVIEW**

- 1. RESULTS TABLE**
- 2. SAMPLING METHODOLOGY**
- 3. DISCUSSION OF RESULTS**
- 4. RECOMMENDATIONS**

#### Appendices:

- A. Sampling Plan
- B. Laboratory Analytical Reports

## **EXECUTIVE SUMMARY:**

The Dobbs Ferry Union Free School District requested lead in water testing of potable water outlets at Springhurst Elementary School, 175 Walgrove Avenue, Dobbs Ferry, NY 10522.

### *Previous Testing (6/22/16)*

In order to determine if lead in water was a concern in the school, a lead in water screening was conducted on June 22, 2016. The testing focused on primary potable water outlets (fountains and kitchen sinks).

First draw and flush samples (30 second) were collected of 44 water fountains and sinks.

All results were below the Lead and Copper action level of 15 ppb. See Table 1A below for specific locations tested.

### *Recent Testing (9/24/16)*

In order to assess the building water outlets a testing of all remaining outlets was performed on September 24, 2016 in accordance with NYS regulations.

Reportedly the outlets were not flushed or used on the day of testing.

First draw and flush samples (30 second) were collected of 117 water fountains and sinks.

**Results of most first draw samples analyzed were below the Lead and Copper Rule action level of 15 ppb. Seven first draw samples were above 15 ppb.**

See Table 1B below for specific locations tested.

See Section 3 Discussion of Results

**1A RESULTS TABLE (6/22 Sampling Event):**

<b>Sample #</b>	<b>Location</b>	<b>1<sup>st</sup> draw</b>	<b>Results</b>	<b>LCR</b>
01	Café Kitchen Faucet - Front	FD	1.36	15
02	Café Kitchen Faucet – Front	FL	--	15
03	Café Kitchen Faucet Wash Sink	FD	3.13	15
04	Café Kitchen Faucet Wash Sink	FL	--	15
05	Café Kitchen Faucet Rear	FD	1.02	15
06	Café Kitchen Faucet Rear	FL	--	15
07	Water Fountain @ Nurse Office	FD	ND	15
08	Water Fountain @ Nurse Office	FL	--	15
09	Water Fountain in M38	FD	5.58	15
10	Water Fountain in M38	FL	--	15
11	Water Fountain in M40	FD	5.06	15
12	Water Fountain in M40	FL	--	15
13	Water Fountain in M39	FD	4.02	15
14	Water Fountain in M39	FL	--	15
15	Water Fountain in M43	FD	2.65	15
16	Water Fountain in M43	FL	--	15
17	Water Fountain in M44	FD	8.06	15
18	Water Fountain in M44	FL	--	15
19	Water Fountain in M47	FD	2.09	15
20	Water Fountain in M47	FL	--	15
21	Water Fountain in M50	FD	5.35	15
22	Water Fountain in M50	FL	--	15
23	Water Fountain in M50	FD	2.05	15
24	Water Fountain in M50	FL	--	15
25	Water Fountain in M1	FD	2.35	15
26	Water Fountain in M1	FL	--	15
27	Kitchen Faucet Faculty Room 1 <sup>st</sup> Floor	FD	1.7	15
28	Kitchen Faucet Faculty Room 1 <sup>st</sup> Floor	FL	--	15
29	Water Fountain in M5	FD	2.84	15
30	Water Fountain in M5	FL	--	15
31	Water Fountain in M3	FD	6.84	15
32	Water Fountain in M3	FL	--	15
33	Water Fountain in M9	FD	4.14	15
34	Water Fountain in M9	FL	--	15
35	Water Fountain in M10	FD	3.81	15
36	Water Fountain in M10	FL	--	15
37	Water Fountain in M11	FD	1.44	15
38	Water Fountain in M11	FL	--	15
39	Water Fountain in M12	FD	ND	15
40	Water Fountain in M12	FL	--	15
41	Water Fountain in M13	FD	ND	15
42	Water Fountain in M13	FL	--	15

43	Water Fountain in M14	FD	ND	15
44	Water Fountain in M14	FL	--	15
45	Water Fountain in M15	FD	ND	15
46	Water Fountain in M15	FL	--	15
47	Water Fountain in M16	FD	ND	15
48	Water Fountain in M16	FL	--	15
49	Water Fountain in M17	FD	ND	15
50	Water Fountain in M17	FL	--	15
51	Water Fountain in M20	FD	ND	15
52	Water Fountain in M20	FL	--	15
53	Water Fountain in G28	FD	ND	15
54	Water Fountain in G28	FL	--	15
55	Water Fountain in G29	FD	ND	15
56	Water Fountain in G29	FL	--	15
57	Water Fountain in G32	FD	ND	15
58	Water Fountain in G32	FL	--	15
59	Water Fountain in G33	FD	ND	15
60	Water Fountain in G33	FL	--	15
61	Water Fountain @ Ground Floor Elevators	FD	ND	15
62	Water Fountain @ Ground Floor Elevators	FL	--	15
63	Water Fountain in M18	FD	ND	15
64	Water Fountain in M18	FL	--	15
65	Water Fountain in M19	FD	ND	15
66	Water Fountain in M19	FL	--	15
67	Water Fountain @ 1 <sup>st</sup> Floor Elevators	FD	ND	15
68	Water Fountain @ 1 <sup>st</sup> Floor Elevators	FL	--	15
69	Water Fountain @ 2 <sup>nd</sup> Floor Girls	FD	1.65	15
70	Water Fountain @ 2 <sup>nd</sup> Floor Girls	FL	--	15
71	Water Fountain in S66	FD	3.48	15
72	Water Fountain in S66	FL	--	15
73	Water Fountain in S68	FD	6.13	15
74	Water Fountain in S68	FL	--	15
75	Water Fountain in S72	FD	3.37	15
76	Water Fountain in S72	FL	--	15
77	Water Fountain in S73	FD	3.94	15
78	Water Fountain in S73	FL	--	15
79	Water Fountain in S71	FD	4.27	15
80	Water Fountain in S71	FL	--	15
81	Water Fountain in S69	FD	5.32	15
82	Water Fountain in S69	FL	--	15
83	Water Fountain in M53	FD	1.5	15
84	Water Fountain in M53	FL	--	15
85	Water Fountain @ Gym L	FD	ND	15
86	Water Fountain @ Gym L	FL	--	15

87	Water Fountain in Gym L	FD	ND	15
88	Water Fountain in Gym L	FL	--	15

**1B RESULTS TABLE (9/24 Sampling Event):**

Sample #	Location	1 <sup>st</sup> draw (FD) or flush (FL)	Results (ppb)	LCR Action Level <sup>(1)</sup> (ppb)
1	01FD-M-Sink-Faculty Lounge	FD	2.0	15
2	02FD-M-S Room M-37 Nurse's Office	FD	43	15
3	03FD-M-S-Room M-38	FD	32	15
4	04FD-M-S-Room M-39	FD	7.3	15
5	05FD-M-S-Room M-40	FD	21	15
6	06FD-M-S-Room M-41	FD	6.5	15
7	07FD-M-S-3 <sup>rd</sup> Grade Girl's Bath – Left Sink	FD	15	15
8	08FD-M-S-3 <sup>rd</sup> Grade Girl's Bath – Right Sink	FD	13	15
9	09FD-M-F-Room M-42	FD	7.2	15
10	10FD-M-F-Room M-42	FD	10	15
11	11FD-M-F-Room M-43	FD	4.4	15
12	12FD-M-F-Room M-44	FD	6.8	15
13	13FD-M-F-Room M-45	FD	7.4	15
14	14FD-M-F-Room M-45	FD	8.2	15
15	15FD-M-F-Room M-46	FD	4.4	15
16	16FD-M-F-Room M-46	FD	2.3	15
17	17FD-M-F-Room M-47	FD	3.3	15
18	18FD-M-S-Custodian Closet by 3 <sup>rd</sup> Grade Entrance (Near M-44)	FD	51	15
19	19FD-M-S-Room M-48	FD	5.8	15
20	20FD-M-F-Room M-46	FD	2.5	15
21	21FD-M-F-Room M-50	FD	5.8	15
22	22FD-M-S-Near Room M-53	FD	4.6	15
23	23FD-M-S-Gym Girl's Bath – Left Sink	FD	1.3	15
24	24FD-M-S-Gym Girl's Bath – Right Sink	FD	1.5	15
25	25FD-M-S-Gym Boy's Bath – Left Sink	FD	1.4	15
26	26FD-M-S-Gym Boy's Bath – Right Sink	FD	1.5	15
27	27FD-M-S-Gym Faculty Bathroom	FD	2.0	15
28	28FD-M-S-Gym Custodial Closet	FD	34	15
29	29FD-M-S-Café Boys Bathroom	FD	1.9	15
30	30FD-M-S-Café Girl's Bathroom	FD	2.1	15
31	31FD-M-S-Café near Girl's Room – Bottle Filler	FD	3.0	15
32	32FD-M-S-Kitchen Bathroom	FD	3.2	15
33	33FD-M-S-Kitchen	FD	4.6	15
34	34FD-M-S-Kitchen	FD	1.9	15
35	35FD-M-S-Kitchen	FD	1.7	15
36	36FD-M-S-Kitchen	FD	2.4	15
37	37FD-M-S-Kitchen	FD	2.9	15

38	38FD-M-S-Kitchen	FD	1.6	15
39	39FD-M-S-Kitchen	FD	2.2	15
40	40FD-M-S-Kitchen	FD	1.6	15
41	41FD-M-S-Kitchen	FD	6.9	15
42	42FD-M-S-Kitchen	FD	<1.0	15
43	43FD-M-S-M-61	FD	7.3	15
44	44FD-M-S-Bathroom Near M-59	FD	12	15
45	45FD-M-S-Room M-57 Art Room – Left Sink	FD	8.3	15
45A	45AFD-M-F-Hallway Left of M-1	FD	3.0	15
46	46FD-M-S-Room M-57 Art Room – 2 <sup>nd</sup> Left Sink	FD	3.4	15
47	47FD-M-S-Room M-57 Art Room – 2 <sup>nd</sup> Right Sink	FD	2.2	15
48	48FD-M-S-Room M-57 Art Room – Right Sink	FD	2.1	15
49	49FD-M-S-M-3	FD	2.7	15
50	50FD-M-S-M-5	FD	3.2	15
51	51FD-M-S-Room M-6	FD	3.7	15
52	52FD-M-S-Room M-7	FD	4.6	15
53	53FD-M-S-Room M-8	FD	3.3	15
54	54FD-M-S-Room M-9	FD	3.3	15
55	55FD-M-S-Room M-10	FD	3.3	15
56	56FD-M-S-Room M-11	FD	2.1	15
57	57FD-M-S-Room M-12	FD	<1.0	15
58	58FD-M-S-Room M-13	FD	<1.0	15
59	59FD-M-S-Room M-14	FD	1.2	15
60	60FD-M-S-Room M-15	FD	<1.0	15
61	61FD-M-F-Room M-16 – Right Fountain	FD	1.1	15
62	62FD-M-F-Room M-16 – Left Fountain	FD	1.7	15
63	63FD-M-S-Room M-16 – Right Sink	FD	<1.0	15
64	64FD-M-S-Room M-16 – Right Sink	FD	<1.0	15
65	65FD-M-S-1 <sup>st</sup> Grade Faculty Bathroom	FD	1.6	15
66	66FD-M-S-Room M-17	FD	<1.0	15
67	67FD-M-S-Room M-18	FD	<1.0	15
68	68FD-M-S-Room M-19	FD	<1.0	15
69	69FD-M-S-Room M-20	FD	<1.0	15
70	70FD-M-S-1 <sup>st</sup> Grade Girl’s Bath – Left Sink	FD	2.1	15
71	71FD-M-S-1 <sup>st</sup> Grade Girl’s Bath – 2 <sup>nd</sup> Left Sink	FD	2.1	15
72	72FD-M-S-1 <sup>st</sup> Grade Girl’s Bath – 2 <sup>nd</sup> Right Sink	FD	2.3	15
73	73FD-M-S-1 <sup>st</sup> Grade Girl’s Bath – Right Sink	FD	2.6	15
74	74FD-M-S-1 <sup>st</sup> Grade Boy’s Bath – Left Sink	FD	1.8	15
75	75FD-M-S-1 <sup>st</sup> Grade Boy’s Bath – 2 <sup>nd</sup> Left Sink	FD	2.0	15
76	76FD-M-S-1 <sup>st</sup> Grade Boy’s Bath – 2 <sup>nd</sup> Right Sink	FD	3.6	15
77	77FD-M-S-1 <sup>st</sup> Grade Boy’s Bath – Right Sink	FD	<1.0	15
78	78FD-M-S-1 <sup>st</sup> Grade Custodial Closet	FD	4.3	15
79	79FD-M-S-Faculty Bathroom Main Office area	FD	1.0	15
80	80FD-M-S-Room M-22	FD	1.5	15
81	81FD-M-S-Room M-24 Mailroom	FD	<1.0	15
82	82FD-G-S-2 <sup>nd</sup> Grade Boy’s Bath – Left Sink	FD	2.9	15
83	83FD-G-S-2 <sup>nd</sup> Grade Boy’s Bath – Middle Sink	FD	<1.0	15

84	84FD-G-S-2 <sup>nd</sup> Grade Boy's Bath – Right Sink	FD	1.1	15
85	85FD-G-S-2 <sup>nd</sup> Grade Girl's Bath – Left Sink	FD	1.6	15
86	86FD-G-S-2 <sup>nd</sup> Grade Girl's Bath – Middle Sink	FD	35	15
87	87FD-G-S-2 <sup>nd</sup> Grade Girl's Bath – Right Sink	FD	1.4	15
88	88FD-G-S-Room G-31	FD	1.4	15
89	89FD-G-S-Room G-32	FD	1.3	15
90	90FD-G-S-Room G-33	FD	<1.0	15
91	91FD-G-S-G Level Faculty Bathroom	FD	<1.0	15
92	92FD-G-S-Room G-26	FD	<1.0	15
93	93FD-G-S-Room G-28	FD	1.9	15
94	94FD-G-S-Room G-29	FD	1.2	15
95	95FD-S-S-5 <sup>th</sup> Grade Faculty Bathroom	FD	6.2	15
96	96FD-S-S-5 <sup>th</sup> Grade Boy's Bath – Left Sink	FD	5.4	15
97	97FD-S-S-5 <sup>th</sup> Grade Boy's Bath – Right Sink	FD	6.3	15
98	98FD-S-S-5 <sup>th</sup> Grade Girl's Bath – Left Sink	FD	7.7	15
99	99FD-S-S-5 <sup>th</sup> Grade Girl's Bath – Right Sink	FD	8.2	15
100	100FD-S-S-Room S-66	FD	6.7	15
101	101FD-S-S-Room S-68	FD	7.8	15
102	102FD-S-S-Room S-69	FD	6.2	15
103	103FD-S-S-Room S-71	FD	3.8	15
104	104FD-S-S-Room S-72	FD	5.1	15
105	105FD-S-S-Room S-73	FD	9.2	15
106	106FD-S-S-Custodians Room	FD	4.9	15
107	107FD-S-S-Custodial Closet Near Café	FD	<1.0	15
108	108FD-M-S-Old Boiler Room	FD	25	15
109	109FD-M-S-M-4 Electric Closet	FD	9.5	15
110	110FD-M-S-New Boiler Room	FD	5.7	15
111	111FD-M-F-Near Boiler Room – Left Fountain	FD	<1.0	15
112	112FD-M-F-Near Boiler Room – Right Fountain	FD	<1.0	15
113	113FD-M-F-Room 41	FD	<1.0	15
114	114FD-M-F-Room M-6 Fountain	FD	<1.0	15
115	115FD-M-F-Room M-7 Fountain	FD	<1.0	15
116	116FD-M-F-Room M-8 Fountain	FD	<1.0	15

<sup>(1)</sup> EPA Lead in Copper Rule (1991) Action Level for water suppliers (municipalities and private wells) and March 2016 Newark Public Schools Lead Water Testing Sampling Plan.

FD – First Draw Sample

FL – Flush Sample (30 sec)

NA – Not Analyzed



## 2 SAMPLING METHODOLOGY:

First Draw Samples - Without allowing any water to spill until sample collection, samples were collected with a relatively slow flow rate in 250 mL bottles prepared with Nitric Acid (HNO<sub>3</sub>) as a preservative.

Flush Samples – After collection of first draw samples the water was allowed to flow at a relatively slow rate for thirty second to flush the fixture and close piping. The flush samples are intended to test the plumbing further upstream from the fixture (behind walls).

The samples were packaged in a cooler and shipped to Pace Analytical, Melville, NY for total lead in potable water analysis (method E200.8 IOC).

## 3 DISCUSSION OF RESULTS:

Only the following sample results were above 15 ppb:

Sample #	Location	1 <sup>st</sup> draw (FD) or flush (FL)	Results (ppb)	LCR Action Level <sup>(1)</sup> (ppb)
2	02FD-M-S Room M-37 Nurse's Office	FD	43	15
3	03FD-M-S-Room M-38	FD	32	15
5	05FD-M-S-Room M-40	FD	21	15
18	18FD-M-S-Custodian Closet by 3 <sup>rd</sup> Grade Entrance (Near M-44)	FD	51	15
28	28FD-M-S-Gym Custodial Closet	FD	34	15
87	86FD-G-S-2 <sup>nd</sup> Grade Girl's Bath – Middle Sink	FD	35	15
109	108FD-M-S-Old Boiler Room	FD	25	15

Since flush samples have not yet been collected, Omega cannot determine if the source of lead is in the fixture or further upstream in the building plumbing. However, since most of the results of samples collected were below 15 ppb, it is not expected that the main building plumbing is the source of lead in water.

The above outlets appear to be sinks only. Aerators, if present and not regularly cleaned or replaced, can build up sediment and cause elevated lead in water readings.

## 4 RECOMMENDATIONS:

### *Short term:*

- Take any outlets with elevated results out of service.
- Prior to collecting flush samples, Omega recommends removing any aerators from these fixtures. Collect another set of first draw samples and flush samples from these specific outlets. When aerators are removed, flush outlet for 5 minute.
- If outlets are not used for several days prior to retesting, the outlet should be run for approximately 1 minute to simulate “normal use” the day before testing. Then allow for a 8-24 hour time of no use prior to sampling.

### *Long Term:*

- If additional testing shows similar results (first draw results above 15 ppb) consider replacing the spout of the fountains (may contain brass, adding to lead levels), installing filters (if practical), or fixture replacement.
- Repeat full building testing on an annual basis. Generally this should be performed in August prior to the start of the school season.
- Develop a Lead in Water Management Plan in accordance with the 2006 EPA 3Ts for Reducing Lead in Drinking Water in Schools.

## A. Sampling Plan

## B. Lead in Water Laboratory Reports





# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: \_\_\_\_\_ of \_\_\_\_\_


<b>Section A</b> Required Client Information:		<b>Section B</b> Required Project Information:		<b>Section C</b> Invoice Information:	
Company:	Omega Environmental	Report To:	Lab@omega-env.com	Attention:	
Address:	280 Huyler Street S. Hackensack, NJ 07606	Copy To:		Company Name:	Omega Environmental
Email To:	Lab@Omega-env.com	Purchase Order No.:		Address:	
Phone:	201-489-8700	Project Name:	Dobbs Ferry Springhurst Elementary	Pace Quote Reference:	
Requested Due Date/TAT:	5 Day TAT	Project Number:	16-1300	Pace Project Manager:	
				Pace Profile #:	

<b>REGULATORY AGENCY</b>	
<input type="checkbox"/> NPDES	<input type="checkbox"/> GROUND WATER
<input type="checkbox"/> UST	<input type="checkbox"/> RCRA
<input type="checkbox"/> DRINKING WATER	<input type="checkbox"/> OTHER
Site Location	NY
STATE:	

ITEM #	Valid Matrix Codes MATRIX CODE DRINKING WATER DW WASTE WATER WW WATER PRODUCT P SOIL/SOLID SL OIL OL WIPE WIP AIR AR OTHER OT TISSUE TS	Section D Required Client Information	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives Unpreserved H2SO4 HNO3 HCl NaOH Na2O3 Methanol Other	Y/N	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
					COMPOSITE START	COMPOSITE END/GRAB							
DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME	DATE	TIME
1	13FD-M-S-Room M-45	DW	G			09/24/16		1					
2	14FD-M-F-Room M-45	DW	G			09/24/16		1					
3	15FD-M-S-Room M-46	DW	G			09/24/16		1					
4	16FD-M-F-Room M-46	DW	G			09/24/16		1					
5	17FD-M-S-Room M-47	DW	G			09/24/16		1					
6	18FD-M-S-Cust. cl by 3rd gd. Ent. (near M-44)	DW	G			09/24/16		1					
7	19FD-M-S-Room M-48	DW	G			09/24/16		1					
8	20FD-M-F-Room M-46	DW	G			09/24/16		1					
9	21FD-M-S-Room M-50	DW	G			09/24/16		1					
10	22FD-M-S-Near Room M-53	DW	G			09/24/16		1					
11	23FD-M-S-Gym Girl's bath- Left Sink	DW	G			09/24/16		1					
12	24FD-M-S-Gym Girl's bath -Right Sink	DW	G			09/24/16		1					

<b>ADDITIONAL COMMENTS</b>		<b>RELINQUISHED BY / AFFILIATION</b>		<b>DATE</b>		<b>TIME</b>		<b>ACCEPTED BY / AFFILIATION</b>		<b>DATE</b>		<b>TIME</b>	
		D. Ekstrand		9/26/16		13:13		D. Ekstrand		9/26/16		13:13	
		K. Ekstrand		9/27/16		16:00		D. Ekstrand		9/27/16		13:13	

<b>SAMPLER NAME AND SIGNATURE</b>		<b>Temp in °C</b>		<b>Received on</b>		<b>Sealed Cooler</b>		<b>Custody</b>		<b>Samples Intact</b>	
PRINT Name of SAMPLER: D. Ekstrand											
SIGNATURE of SAMPLER: <i>[Signature]</i>											
DATE Signed (MM/DD/YYYY):		9/26/16									



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b> Required Client Information:		<b>Section B</b> Required Project Information:		<b>Section C</b> Invoice Information:	
Company:	Omega Environmental	Report To:	Lab@omega-env.com	Attention:	
Address:	280 Huyler Street S. Hackensack, NJ 07606	Copy To:		Company Name:	Omega Environmental
Email To:	Lab@Omega-env.com	Purchase Order No.:		Address:	
Phone:	201-489-8700	Project Name:	Dobbs Ferry Springhurst Elementary	Pace Quote Reference:	
Requested Due Date/TAT:	5 Day TAT	Project Number:	16-1300	Pace Project Manager:	
				Pace Profile #:	

Page: \_\_\_\_\_ of \_\_\_\_\_

**REGULATORY AGENCY**

NPDES  GROUND WATER  DRINKING WATER

UST  RCRA  OTHER \_\_\_\_\_

Site Location STATE: NY

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX CODE	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
					COMPOSITE START	COMPOSITE END/GRAB						
1	25FD-M-S-Gym Boy's Bath - Left - Sink	DW	DW	G	09/24/16	09/24/16	1	1	Unpreserved	X	X	
2	26FD-M-S-Gym Boy's Bath- Right Sink	DW	DW	G	09/24/16	09/24/16	1	1	HCl	X	X	
3	27FD-M-S-Gm faculty bathroom	DW	DW	G	09/24/16	09/24/16	1	1	HNO <sub>3</sub>	X	X	
4	28FD-M-S-Gym Custodial closet	DW	DW	G	09/24/16	09/24/16	1	1	H <sub>2</sub> SO <sub>4</sub>	X	X	
5	29FD-M-S-Café Boy's bathroom	DW	DW	G	09/24/16	09/24/16	1	1	NaOH	X	X	
6	30FD-M-S-Café Girl's bathroom	DW	DW	G	09/24/16	09/24/16	1	1	Na <sub>2</sub> O <sub>3</sub>	X	X	
7	31FD-M-S-Café near Girl's rm--Bottle Filler	DW	DW	G	09/24/16	09/24/16	1	1	Methanol	X	X	
8	32FD-M-S-Kitchen bathroom	DW	DW	G	09/24/16	09/24/16	1	1	Other	X	X	
9	33FD-M-S-kitchen	DW	DW	G	09/24/16	09/24/16	1	1				
10	34FD-M-S-kitchen	DW	DW	G	09/24/16	09/24/16	1	1				
11	35FD-M-S-kitchen	DW	DW	G	09/24/16	09/24/16	1	1				
12	36FD-M-S-kitchen	DW	DW	G	09/24/16	09/24/16	1	1				

RELIQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
<i>D. Ekstrand</i>	9/26/16		<i>D. Ekstrand</i>	9/26/16	13:13	Temp in °C
<i>Kyle B...</i>	9/26/16	13:13	<i>[Signature]</i>	9/26/16	13:13	Received on Ice (Y/N)
<i>[Signature]</i>	9/27/16	10:00	<i>[Signature]</i>	9/26/16		Sealed Cooler (Y/N)
						Custody (Y/N)
						Samples Intact (Y/N)

**SAMPLER NAME AND SIGNATURE**

PRINT Name of SAMPLER: D. Ekstrand

SIGNATURE of SAMPLER: *[Signature]*

DATE Signed (MM/DD/YYYY): 9/26/16

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.

F-ALL-Q-020rev.08, 12-Oct-2007











# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b> Required Client Information:		<b>Section B</b> Required Project Information:		<b>Section C</b> Invoice Information:	
Company: Omega Environmental	Report To: Lab@omega-env.com	Attention:	Company Name: Omega Environmental	Page: _____	of _____
Address: 280 Huyler Street	Copy To:	Address:	Address:		
S. Hackensack, NJ 07606	Purchase Order No.:	Pace Quote Reference:	REGULATORY AGENCY		
Email To: Lab@Omega-env.com	Project Name: Dobbs Ferry Springhurst Elementary	Pace Project Manager:	<input type="checkbox"/> NPDES <input type="checkbox"/> GROUND WATER <input checked="" type="checkbox"/> DRINKING WATER		
Phone: 201-489-8700 Fax:	Project Number: 16-1300	Pace Profile #:	<input type="checkbox"/> UST <input type="checkbox"/> RCRA <input type="checkbox"/> OTHER		
Requested Due Date/TAT: 5 Day TAT			Site Location STATE: NY		

ITEM #	Section D Required Client Information	Valid Matrix Codes MATRIX CODE DRINKING WATER DW WASTE WATER WW PRODUCT P SOIL/SOLID SL OIL OL WIPE WIP AIR AR OTHER OT TISSUE TS	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives H <sub>2</sub> SO <sub>4</sub> HNO <sub>3</sub> HCl NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> Methanol Other	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
					COMPOSITE START	COMPOSITE END/GRAB						
1	72FD-M-S-1st grd Girl's bath - 2nd Right Sink		DW G	G			09/24/16	1				
2	73FD-M-S-1st grade Girl's bath-Right Sink		DW G	G			09/24/16	1				
3	74FD-M-S-1st grade Boy's bath-Left Sink		DW G	G			09/24/16	1				
4	75FD-M-S-1st grd Boy's bath- 2nd Left Sink		DW G	G			09/24/16	1				
5	76FD-M-S-1st grd Boy's bath-2nd Right Sink		DW G	G			09/24/16	1				
6	77FD-M-S-1st grd Boy's bath-Right Sink		DW G	G			09/24/16	1				
7	78FD-M-S-1st grade custodial closet		DW G	G			09/24/16	1				
8	79FD-M-S-Faculty bathroom main off area		DW G	G			09/24/16	1				
9	80FD-M-S-Room M-22		DW G	G			09/24/16	1				
10	81FD-M-S-Room M-24 mailroom		DW G	G			09/24/16	1				
11	82FD-G-S-2nd grd Boy's bath-Left Sink		DW G	G			09/24/16	1				
12	83FD-G-S-2nd grd Boy's bath-Middle Sink		DW G	G			09/24/16	1				

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	D. Ekstrand	9/26/16					
	<i>[Signature]</i>	9/26/16	13:13	<i>[Signature]</i>	9/26/16		
	<i>[Signature]</i>	9/27/16	11:00	<i>[Signature]</i>	9/26/16		

Temp in °C	Received on Ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)
DATE SIGNED (MM/DD/YYYY): 9/26/16		DATE SIGNED (MM/DD/YYYY): 9/26/16	
PRINT Name of SAMPLER: D. Ekstrand		SIGNATURE of SAMPLER: <i>[Signature]</i>	
SAMPLER NAME AND SIGNATURE			



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b> Required Client Information:		<b>Section B</b> Required Project Information:		<b>Section C</b> Invoice Information:	
Company: Omega Environmental	Report To: Lab@omega-env.com	Company Name: Omega Environmental	Attention:	Page: _____ of _____	
Address: 280 Huyler Street	Copy To:	Address:			
Email To: Lab@Omega-env.com	Purchase Order No.:	Regulatory Agency:	<input type="checkbox"/> NPDES <input type="checkbox"/> GROUND WATER <input checked="" type="checkbox"/> DRINKING WATER		
Phone: 201-489-8700 Fax:	Project Name: Dobbs Ferry Springhurst Elementary	Site Location:	<input type="checkbox"/> UST <input type="checkbox"/> RCRA <input type="checkbox"/> OTHER		
Requested Due Date/TAT: 5 Day TAT	Project Number: 16-1300	STATE: NY			

ITEM #	Valid Matrix Codes MATRIX CODE DRINKING WATER DW WASTE WATER WW PRODUCT P SOIL/SOLID SL OIL OL WIPE WP AIR AR OTHER OT TISSUE TS	Required Client Information <b>SAMPLE ID</b> (A-Z, 0-9 /, .) Sample IDs MUST BE UNIQUE	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS	Preservatives Unpreserved H <sub>2</sub> SO <sub>4</sub> HNO <sub>3</sub> HCl NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> Methanol Other	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
			COMPOSITE START	COMPOSITE END/GRAB							
1		84FD-G-S-2nd grd Boy's bath - Right Sink	DATE	TIME	G	DW	1				
2		85FD-G-S-2nd grd Girl's bath- Left Sink	09/24/16		G	DW	1				
3		86FD-G-S-2nd grd Girl's bath- Middle Sink	09/24/16		G	DW	1				
4		87FD-G-S-2nd grd Girl's bath- Right Sink	09/24/16		G	DW	1				
5		88FD-G-S-Room G-31	09/24/16		G	DW	1				
6		89FD-G-S-Room G-32	09/24/16		G	DW	1				
7		90FD-G-S-Room G-33	09/24/16		G	DW	1				
8		91FD-G-S-G level faculty bathroom	09/24/16		G	DW	1				
9		92FD-G-S-Room G-26	09/24/16		G	DW	1				
10		93FD-G-S-Room G-28	09/24/16		G	DW	1				
11		94FD-G-S-Room G-29	09/24/16		G	DW	1				
12		95FD-S-S-5th grade faculty bathroom	09/24/16		G	DW	1				

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION		ACCEPTED BY / AFFILIATION		SAMPLE CONDITIONS			
	DATE	TIME	DATE	TIME	Temp in °C	Received on Ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)
	9/26/16		9/26/16	13:13				
D. Ekstrand								
<i>[Signature]</i>								
<i>[Signature]</i>								

<b>SAMPLER NAME AND SIGNATURE</b>	
PRINT Name of SAMPLER: D. Ekstrand	DATE Signed (MM/DD/YYYY): 9/26/16
SIGNATURE of SAMPLER: <i>[Signature]</i>	





# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: _____ of _____	
<b>Section A</b>	
Required Client Information:	
Company: Omega Environmental	Report To: Lab@omega-env.com
Address: 280 Huyler Street	Copy To:
S. Hackensack, NJ 07606	
Email To: Lab@Omega-env.com	Purchase Order No.:
Phone: 201-489-8700	Project Name: Dobbs Ferry Springhurst Elementary
Fax:	Project Number: 16-1300
Requested Due Date/TAT: 5 Day TAT	
<b>Section B</b>	
Required Project Information:	
Company Name: Omega Environmental	
Address:	
Pace Quote Reference:	
Pace Project Manager:	
Pace Profile #:	
<b>Section C</b>	
Invoice Information:	
Attention:	
REGULATORY AGENCY	
<input type="checkbox"/> NPDES	<input type="checkbox"/> GROUND WATER
<input type="checkbox"/> UST	<input type="checkbox"/> RCRA
<input type="checkbox"/> DRINKING WATER	<input type="checkbox"/> OTHER
Site Location	STATE: NY
<b>Section D</b>	
Required Client Information	
<b>SAMPLE ID</b> (A-Z, 0-9 / -)	
Sample IDs MUST BE UNIQUE	
100020	
Pace Project No. / Lab I.D.	
Residual Chlorine (Y/N)	
LEAD IN WATER 200.8	
Analysis Test	
Preservatives	
# OF CONTAINERS	
SAMPLE TEMP AT COLLECTION	
COLLECTED	
MATRIX CODE (see valid codes to left)	
SAMPLE TYPE (G=GRAB C=COMP)	
Valid Matrix Codes	
MATRIX CODE	
DRINKING WATER DW	
WASTE WATER WW	
PRODUCT P	
SOLID/SOLID SL	
OIL OL	
WIPE WP	
AIR AR	
OTHER OT	
TISSUE TS	
ITEM #	ADDITIONAL COMMENTS
1	108FD-M-S-Old boiler room
2	109FD-M-S-M-4 Electric closet
3	110FD-M-S-New boiler room
4	111FD-M-F-Near boiler room - Left Fountain
5	112FD-M-F-Near boiler rm - Right Fountain
6	113FD-M-F-Room 41
7	114FD-M-F-Room M-6 Fountain
8	115FD-M-F-Room M-7 Fountain
9	116FD-M-S-Room M-8 Fountain
10	
11	
12	
<b>Section E</b>	
RELINQUISHED BY / AFFILIATION	
DATE	
TIME	
ACCEPTED BY / AFFILIATION	
DATE	
TIME	
SAMPLE CONDITIONS	
Temp in °C	Received on
	Ice (Y/N)
	Custody (Y/N)
	Sealed Cooler (Y/N)
	Samples Intact (Y/N)
<b>Section F</b>	
SAMPLER NAME AND SIGNATURE	
PRINT Name of SAMPLER: D. Ekstrand	
SIGNATURE of SAMPLER:	
DATE Signed (MM/DD/YYYY): 9/26/16	
DATE Signed (MM/DD/YYYY): 9/26/16 13:13	
DATE Signed (MM/DD/YYYY): 9/27/16 1600	
DATE Signed (MM/DD/YYYY): 9/27/16 1313	

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-001  
Client Sample ID. : 01FD-M-S-FACULTY LOUNGE

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	2.0		1	ug/L	15	10/03/2016 4:55 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-002**  
**Client Sample ID. : 02FD-M-S-ROOM M-37 NURSES OFFICE**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 43	*	1	ug/L	15	10/03/2016 4:58 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-003  
Client Sample ID. : 03FD-M-S-ROOM M-38

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	* 32	*	1	ug/L	15	10/03/2016 5:01 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
 280 Huyler Street  
 South Hackensack, NJ 07606

**Lab No. : 1610020-004**  
**Client Sample ID. : 04FD-M-S-ROOM M-39**

Attn To : Michael Levay  
 Federal ID :

**DOBBS FERRY SPRINGHURST  
 ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

---

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG <u>Container:</u>
Lead	7.3		1	ug/L	15	10/03/2016 5:04 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
 280 Huyler Street  
 South Hackensack, NJ 07606

**Lab No. : 1610020-005**  
**Client Sample ID. : 05FD-M-S-ROOM M-40**

**Attn To :** Michael Levay  
 Federal ID :  
 Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

**DOBBS FERRY SPRINGHURST  
 ELEMENTARY**

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG	<u>Container:</u>
Lead	* 21	*	1	ug/L	15	10/03/2016 5:07 PM		Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-006**  
**Client Sample ID. : 06FD-M-S-ROOM M-41**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.5		1	ug/L	15	10/03/2016 5:10 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**  
**Attn To : Michael Levay**  
 Federal ID :  
 Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

**Lab No. : 1610020-007**  
**Client Sample ID. : 07FD-M-S-3RD GRADE GIRLS BATH-LEFT SINK**  
**DOBBS FERRY SPRINGHURST ELEMENTARY**

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG	<u>Container:</u>
Lead	15		1	ug/L	15	10/03/2016 5:13 PM		Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

*Elizabeth Harrison*

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-008**  
**Client Sample ID. : 08FD-M-S-3RD GRADE GIRLS BATH-  
RIGHT SINK**  
**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Attn To : Michael Levay  
Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	13		1	ug/L	15	10/03/2016 5:30 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-009**  
**Client Sample ID. : 09FD-M-F-ROOM M-42**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.2		1	ug/L	15	10/03/2016 5:33 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
 280 Huyler Street  
 South Hackensack, NJ 07606

**Lab No. : 1610020-010**  
**Client Sample ID. : 10FD-M-S-ROOM M-42**

**Attn To :** Michael Levay  
 Federal ID :

**DOBBS FERRY SPRINGHURST  
 ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

---

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG <u>Container:</u>
Lead	10		1	ug/L	15	10/03/2016 5:36 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-011**  
**Client Sample ID. : 11FD-M-F-ROOM M-43**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.4		1	ug/L	15	10/03/2016 5:39 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-012**  
**Client Sample ID. : 12FD-M-S-ROOM M-44**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.8		1	ug/L	15	10/03/2016 5:42 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-013**  
**Client Sample ID. : 13FD-M-S-ROOM M-45**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.4		1	ug/L	15	10/03/2016 5:45 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-014**  
**Client Sample ID. : 14FD-M-F-ROOM M-45**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	8.2		1	ug/L	15	10/03/2016 5:48 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-015**  
**Client Sample ID. : 15FD-M-S-ROOM M-46**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.4	M+	1	ug/L	15	10/03/2016 5:51 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-016  
Client Sample ID. : 16FD-M-F-ROOM M-46

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	2.3		1	ug/L	15	10/03/2016 6:05 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-017**  
**Client Sample ID. : 17FD-M-S-ROOM M-47**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.3		1	ug/L	15	10/03/2016 6:08 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-018**  
**Client Sample ID. : 18FD-M-S-CUST CL BY 3RD GD. ENT.**  
**(NEAR M-44)**  
**DOBBS FERRY SPRINGHURST**  
**ELEMENTARY**

Attn To : Michael Levay  
Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	* 51	*	1	ug/L	15	10/03/2016 6:11 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-019  
Client Sample ID. : 19FD-M-S-ROOM M-48

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.8		1	ug/L	15	10/03/2016 6:14 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-020  
Client Sample ID. : 20FD-M-F-ROOM M-46

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	2.5		1	ug/L	15	10/03/2016 6:17 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-021  
Client Sample ID. : 21FD-M-S-ROOM M-50

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.8		1	ug/L	15	10/03/2016 6:20 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-022  
Client Sample ID. : 22FD-M-S-NEAR ROOM M-53

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	4.6		1	ug/L	15	10/03/2016 6:23 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-023**  
**Client Sample ID. : 23FD-M-S-GYM GIRLS BATH-LEFT SINK**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.3		1	ug/L	15	10/03/2016 6:26 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-024**  
**Client Sample ID. : 24FD-M-S-GYM GIRLS BATH-RIGHT SINK**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.5		1	ug/L	15	10/03/2016 6:40 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-025**  
**Client Sample ID. : 25FD-M-S-GYM BOYS BATH-LEFT -SINK**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.4		1	ug/L	15	10/03/2016 6:43 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-026**  
**Client Sample ID. : 26FD-M-S-GYM BOYS BATH-RIGHT -SINK**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.5		1	ug/L	15	10/03/2016 6:46 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-027**  
**Client Sample ID. : 27FD-M-S-GM FACULTY BATHROOM**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.0		1	ug/L	15	10/03/2016 6:49 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-028**  
**Client Sample ID. : 28FD-M-S-GYM CUSTODIAL CLOSET**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 34	*	1	ug/L	15	10/03/2016 6:52 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-029**  
**Client Sample ID. : 29FD-M-S-CAFE BOYS BATHROOM**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.9		1	ug/L	15	10/03/2016 6:55 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-030**  
**Client Sample ID. : 30FD-M-S-CAFE GIRLS BATHROOM**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.1		1	ug/L	15	10/03/2016 6:58 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**  
**Attn To : Michael Levay**  
 Federal ID :  
 Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

**Lab No. : 1610020-031**  
**Client Sample ID. : 31FD-M-S-CAFE NEAR GIRLS RM-  
 BOTTLE FILLER  
 DOBBS FERRY SPRINGHURST  
 ELEMENTARY**

---

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG	<u>Container:</u>
Lead	3.0		1	ug/L	15	10/03/2016 7:01 PM		Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-032**  
**Client Sample ID. : 32FD-M-S-KITCHEN BATHROOM**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.2		1	ug/L	15	10/03/2016 7:15 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
 280 Huyler Street  
 South Hackensack, NJ 07606

**Lab No. : 1610020-033**  
**Client Sample ID. : 33FD-M-S-KITCHEN**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
 ELEMENTARY**

Federal ID :  
 Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

<u>Analytical Method:</u> E200.8 : IOC							<u>Analyst:</u> AG
<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.6		1	ug/L	15	10/03/2016 7:18 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-034**  
**Client Sample ID. : 34FD-M-S-KITCHEN**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.9		1	ug/L	15	10/03/2016 7:21 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-035**  
**Client Sample ID. : 35FD-M-S-KITCHEN**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.7		1	ug/L	15	10/03/2016 7:24 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-036**  
**Client Sample ID. : 36FD-M-S-KITCHEN**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.4		1	ug/L	15	10/03/2016 7:27 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-037**  
**Client Sample ID. : 37FD-M-S-KITCHEN**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.9		1	ug/L	15	10/03/2016 7:30 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-038**  
**Client Sample ID. : 38FD-M-S-KITCHEN**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.6		1	ug/L	15	10/03/2016 7:33 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-039**  
**Client Sample ID. : 39FD-M-S-KITCHEN**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG <u>Container:</u>
Lead	2.2		1	ug/L	15	10/03/2016 7:36 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-040**  
**Client Sample ID. : 40FD-M-S-KITCHEN**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.6		1	ug/L	15	10/03/2016 7:50 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-041**  
**Client Sample ID. : 41FD-M-S-KITCHEN**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.9		1	ug/L	15	10/03/2016 7:53 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-042  
Client Sample ID. : 42FD-M-S-KITCHEN

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	< 1.0		1	ug/L	15	10/03/2016 7:56 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-043  
Client Sample ID. : 43FD-M-S-M-61

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	7.3		1	ug/L	15	10/03/2016 7:59 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
 280 Huyler Street  
 South Hackensack, NJ 07606  
 Attn To : Michael Levay

**Lab No. : 1610020-044**  
**Client Sample ID. : 45FD-M-S-ROOM M-57 ART ROOM-LEFT**  
**SINK**  
**DOBBS FERRY SPRINGHURST**  
**ELEMENTARY**

Federal ID :  
 Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

---

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG	<u>Container:</u>
Lead	8.3		1	ug/L	15	10/03/2016 8:02 PM		Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-045  
Client Sample ID. : 45AFD-M-F-HALWAY LEFT OF M-1

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	3.0		1	ug/L	15	10/03/2016 8:05 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street

South Hackensack, NJ 07606

Attn To : Michael Levay

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Lab No. : 1610020-046

Client Sample ID. : 46FD-M-S-RM M-57 ART RM-2ND LEFT  
SINK

DOBBS FERRY SPRINGHURST  
ELEMENTARY

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	3.4		1	ug/L	15	10/03/2016 8:08 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street

South Hackensack, NJ 07606

Attn To : Michael Levay

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Lab No. : 1610020-047

Client Sample ID. : 47FD-M-S-RM M-57 ART RM-2ND RIGHT  
SINK

DOBBS FERRY SPRINGHURST  
ELEMENTARY

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	2.2	M+	1	ug/L	15	10/03/2016 8:11 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-048**  
**Client Sample ID. : 48FD-M-S-RM M-57 ART RM-RIGHT SINK**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.1		1	ug/L	15	10/03/2016 8:25 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-049  
Client Sample ID. : 49FD-M-S-M-3

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.7		1	ug/L	15	10/03/2016 8:28 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-050**  
**Client Sample ID. : 50FD-M-S-M-5**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.2		1	ug/L	15	10/03/2016 8:31 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-051**  
**Client Sample ID. : 51FD-M-S-ROOM M-6**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.7		1	ug/L	15	10/03/2016 8:34 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-052**  
**Client Sample ID. : 52FD-M-S-ROOM M-7**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.6		1	ug/L	15	10/03/2016 8:37 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-053**  
**Client Sample ID. : 53FD-M-S-ROOM M-8**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.3		1	ug/L	15	10/03/2016 8:40 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-054**  
**Client Sample ID. : 54FD-M-S-ROOM M-9**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.3		1	ug/L	15	10/03/2016 8:43 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-055**  
**Client Sample ID. : 55FD-M-S-ROOM M-10**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.3		1	ug/L	15	10/03/2016 8:46 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-056**  
**Client Sample ID. : 56FD-M-S-ROOM M-11**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.1		1	ug/L	15	10/03/2016 9:00 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-057**  
**Client Sample ID. : 57FD-M-S-ROOM M-12**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 9:03 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-058**  
**Client Sample ID. : 58FD-M-S-ROOM M-13**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 9:06 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-059**  
**Client Sample ID. : 59FD-M-S-ROOM M-14**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.2		1	ug/L	15	10/03/2016 9:09 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-060**  
**Client Sample ID. : 60FD-M-S-ROOM M-15**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 9:12 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**  
**Attn To : Michael Levay**  
 Federal ID :  
 Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

**Lab No. : 1610020-061**  
**Client Sample ID. : 61FD-M-S-ROOM M-16 - RIGHT**  
**FOUNTAIN**  
**DOBBS FERRY SPRINGHURST**  
**ELEMENTARY**

---

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG	<u>Container:</u>
Lead	1.1		1	ug/L	15	10/03/2016 9:15 PM		Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

*Elizabeth Harrison*

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
 280 Huyler Street  
 South Hackensack, NJ 07606

**Lab No. : 1610020-062**  
**Client Sample ID. : 62FD-M-S-ROOM M-16 - LEFT FOUNTAIN**

Attn To : Michael Levay  
 Federal ID :

**DOBBS FERRY SPRINGHURST  
 ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

---

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG <u>Container:</u>
Lead	1.7		1	ug/L	15	10/03/2016 9:18 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-063**  
**Client Sample ID. : 63FD-M-S-ROOM M-16 - RIGHT SINK**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 9:21 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-064**  
**Client Sample ID. : 64FD-M-S-ROOM M-16 - RIGHT SINK**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 9:36 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-065**  
**Client Sample ID. : 65FD-M-S-1ST GRADE FACULTY BATHROOM**  
**DOBBS FERRY SPRINGHURST ELEMENTARY**

Attn To : Michael Levay  
Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.6		1	ug/L	15	10/03/2016 9:39 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-066  
Client Sample ID. : 66FD-M-S-ROOM M-17

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 9:41 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-067  
Client Sample ID. : 67FD-M-S-ROOM M-18

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 9:44 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-068  
Client Sample ID. : 68FD-M-S-ROOM M-19

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 9:47 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
 280 Huyler Street  
 South Hackensack, NJ 07606

**Lab No. : 1610020-069**  
**Client Sample ID. : 69FD-M-S-ROOM M-20**

Attn To : Michael Levay  
 Federal ID :

**DOBBS FERRY SPRINGHURST  
 ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

---

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG <u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 9:50 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street

South Hackensack, NJ 07606

Attn To : Michael Levay

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Lab No. : 1610020-070

Client Sample ID. : 70FD-M-S-1ST GRD GIRLS BATH-LEFT  
SINK

DOBBS FERRY SPRINGHURST  
ELEMENTARY

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	2.1		1	ug/L	15	10/03/2016 9:53 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-071**  
**Client Sample ID. : 71FD-M-S-1ST GRD GIRLS BATH-2ND**  
**LEFT SINK**  
**DOBBS FERRY SPRINGHURST**  
**ELEMENTARY**

Attn To : Michael Levay  
Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.1		1	ug/L	15	10/03/2016 9:56 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**

280 Huyler Street  
South Hackensack, NJ 07606

Attn To : Michael Levay

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Lab No. : 1610020-072

Client Sample ID. : 72FD-M-S-1ST GRD GIRLS BATH-2ND  
RIGHT SINK  
DOBBS FERRY SPRINGHURST  
ELEMENTARY

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	2.3		1	ug/L	15	10/03/2016 10:11 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
 280 Huyler Street  
 South Hackensack, NJ 07606  
 Attn To : Michael Levay  
 Federal ID :  
 Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

**Lab No. : 1610020-073**  
**Client Sample ID. : 73FD-M-S-1ST GRD GIRLS BATH-RIGHT SINK**  
**DOBBS FERRY SPRINGHURST ELEMENTARY**

---

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.6		1	ug/L	15	10/03/2016 10:14 PM	Container-01 of 01

---

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**

280 Huyler Street  
South Hackensack, NJ 07606  
Attn To : Michael Levay

Lab No. : 1610020-074

Client Sample ID. : 74FD-M-S-1ST GRD BOYS BATH-LEFT  
SINK  
DOBBS FERRY SPRINGHURST  
ELEMENTARY

Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	1.8		1	ug/L	15	10/03/2016 10:16 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-075**  
**Client Sample ID. : 75FD-M-S-1ST GRD BOYS BATH-2ND**  
**LEFT SINK**  
**DOBBS FERRY SPRINGHURST**  
**ELEMENTARY**

Attn To : Michael Levay  
Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	2.0		1	ug/L	15	10/03/2016 10:19 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-076**  
**Client Sample ID. : 76FD-M-S-1ST GRD BOYS BATH-2ND**  
**RIGHT SINK**  
**DOBBS FERRY SPRINGHURST**  
**ELEMENTARY**

Attn To : Michael Levay  
Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.6		1	ug/L	15	10/03/2016 10:22 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street

South Hackensack, NJ 07606

Attn To : Michael Levay

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Lab No. : 1610020-077

Client Sample ID. : 77FD-M-S-1ST GRD BOYS BATH-RIGHT  
SINK

DOBBS FERRY SPRINGHURST  
ELEMENTARY

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	< 1.0		1	ug/L	15	10/03/2016 10:25 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-078**  
**Client Sample ID. : 78FD-M-S-1ST GRADE CUSTODIAL CLOSET**  
**DOBBS FERRY SPRINGHURST ELEMENTARY**

Attn To : Michael Levay  
Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.3		1	ug/L	15	10/03/2016 10:28 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**

280 Huyler Street  
South Hackensack, NJ 07606

Attn To : Michael Levay

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Lab No. : 1610020-079

Client Sample ID. : 79FD-M-S-FACULTY BATHROOM MAIN  
OFF AREA  
DOBBS FERRY SPRINGHURST  
ELEMENTARY

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	1.0		1	ug/L	15	10/03/2016 10:31 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-080  
Client Sample ID. : 80FD-M-S-ROOM M-22

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.5		1	ug/L	15	10/03/2016 10:46 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**

**Lab No. : 1610020-081**  
**Client Sample ID. : 81FD-M-S-ROOM M-24 MAILROOM**

**Attn To :** Michael Levay  
 Federal ID :

**DOBBS FERRY SPRINGHURST  
 ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

---

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 10:49 PM	Container-01 of 01

---

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street

South Hackensack, NJ 07606

Attn To : Michael Levay

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Lab No. : 1610020-082

Client Sample ID. : 82FD-G-S-2ND GRD BOYS BATH-LEFT  
SINK

DOBBS FERRY SPRINGHURST  
ELEMENTARY

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	2.9		1	ug/L	15	10/03/2016 10:52 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-083**  
**Client Sample ID. : 83FD-G-S-2ND GRD BOYS BATH-MIDDLE SINK**  
**DOBBS FERRY SPRINGHURST ELEMENTARY**

Attn To : Michael Levay  
Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 10:54 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606  
Attn To : Michael Levay

Lab No. : 1610020-084  
Client Sample ID. : 84FD-G-S-2ND GRD BOYS BATH- RIGHT  
SINK  
DOBBS FERRY SPRINGHURST  
ELEMENTARY

Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	1.1		1	ug/L	15	10/03/2016 10:57 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street

South Hackensack, NJ 07606

Attn To : Michael Levay

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Lab No. : 1610020-085

Client Sample ID. : 85FD-G-S-2ND GRD GIRLS BATH- LEFT  
SINK

DOBBS FERRY SPRINGHURST  
ELEMENTARY

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	1.6		1	ug/L	15	10/03/2016 11:00 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-086**  
**Client Sample ID. : 86FD-G-S-2ND GRD GIRLS BATH-  
MIDDLE SINK  
DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Attn To : Michael Levay  
Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	* 35	*	1	ug/L	15	10/03/2016 11:03 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-087  
Client Sample ID. : 87FD-G-S-2ND GRD GIRLS BATH- RIGHT  
SINK  
DOBBS FERRY SPRINGHURST  
ELEMENTARY

Attn To : Michael Levay  
Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	1.4		1	ug/L	15	10/03/2016 11:06 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**

**Lab No. : 1610020-088**  
**Client Sample ID. : 88FD-G-S-ROOM G-31**

**Attn To :** Michael Levay  
 Federal ID :

**DOBBS FERRY SPRINGHURST  
 ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

---

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.4		1	ug/L	15	10/03/2016 11:21 PM	Container-01 of 01

---

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-089  
Client Sample ID. : 89FD-G-S-ROOM G-32

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.3		1	ug/L	15	10/03/2016 11:24 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-090**  
**Client Sample ID. : 90FD-G-S-ROOM G-33**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 11:26 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-091**  
**Client Sample ID. : 91FD-G-S-G LEVEL FACULTY BATHROOM**  
**DOBBS FERRY SPRINGHURST ELEMENTARY**

Attn To : Michael Levay  
Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 11:29 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-092**  
**Client Sample ID. : 92FD-G-S-ROOM G-26**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/03/2016 11:32 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-093  
Client Sample ID. : 93FD-G-S-ROOM G-28

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	1.9		1	ug/L	15	10/03/2016 11:35 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-094**  
**Client Sample ID. : 94FD-G-S-ROOM G-29**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	1.2		1	ug/L	15	10/03/2016 11:38 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**  
 Type : Potable Water  
 Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
 The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
**280 Huyler Street**  
**South Hackensack, NJ 07606**  
**Attn To : Michael Levay**  
 Federal ID :  
 Collected : 09/24/2016 12:00 AM Point No  
 Received : 09/28/2016 12:00 PM Location:  
 Collected By : DE99

**Lab No. : 1610020-095**  
**Client Sample ID. : 95FD-S-S-5TH GRADE FACULTY BATHROOM**  
**DOBBS FERRY SPRINGHURST ELEMENTARY**

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Analyst:</u> AG <u>Container:</u>
Lead	6.2	M-	1	ug/L	15	10/03/2016 11:41 PM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
 B = Found in Blank  
 D.F. = Dilution Factor D = Results for Dilution  
 c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
 H = Received/analyzed outside of analytical holding time  
 J = Estimated value - below calibration range  
 M-, M+ = Matrix Spike recovery below / above control limit  
 N = Indicates presumptive evidence of compound  
 P = Duplicate RPD outside of control limit  
 r = Reporting limit below calibration range. Value estimated.  
 S = Recovery outside of control limits for this analyte  
 + = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
 Result(s) reported meet(s) Regulatory Limit(s).  
 Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
 Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.  
 This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606  
Attn To : Michael Levay

Lab No. : 1610020-096  
Client Sample ID. : 96FD-S-S-5TH GRD BOYS BATH-LEFT  
SINK  
DOBBS FERRY SPRINGHURST  
ELEMENTARY

Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	5.4		1	ug/L	15	10/04/2016 12:41 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606  
Attn To : Michael Levay

Lab No. : 1610020-097  
Client Sample ID. : 97FD-S-S-5TH GRD BOYS BATH-RIGHT  
SINK  
DOBBS FERRY SPRINGHURST  
ELEMENTARY

Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	6.3		1	ug/L	15	10/04/2016 12:44 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street

South Hackensack, NJ 07606

Attn To : Michael Levay

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Lab No. : 1610020-098

Client Sample ID. : 98FD-S-S-5TH GRD GIRLS BATH-LEFT  
SINK

DOBBS FERRY SPRINGHURST  
ELEMENTARY

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	7.7		1	ug/L	15	10/04/2016 12:47 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606  
Attn To : Michael Levay

Lab No. : 1610020-099  
Client Sample ID. : 99FD-S-S-5TH GRD GIRLS BATH-RIGHT  
SINK  
DOBBS FERRY SPRINGHURST  
ELEMENTARY

Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	8.2		1	ug/L	15	10/04/2016 12:50 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-100**  
**Client Sample ID. : 100FD-S-S-ROOM S-66**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.7		1	ug/L	15	10/04/2016 12:52 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-101**  
**Client Sample ID. : 101FD-S-S-ROOM S-68**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	7.8		1	ug/L	15	10/04/2016 12:55 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-102**  
**Client Sample ID. : 102FD-S-S-ROOM S-69**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	6.2		1	ug/L	15	10/04/2016 12:58 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-103**  
**Client Sample ID. : 103FD-S-S-ROOM S-71**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	3.8		1	ug/L	15	10/04/2016 1:01 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-104**  
**Client Sample ID. : 104FD-S-S-ROOM S-72**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.1		1	ug/L	15	10/04/2016 1:16 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-105**  
**Client Sample ID. : 105FD-S-S-ROOM S-73**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.2		1	ug/L	15	10/04/2016 1:19 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-106**  
**Client Sample ID. : 106FD-S-S-CUSTODIANS ROOM**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	4.9		1	ug/L	15	10/04/2016 1:22 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**

280 Huyler Street  
South Hackensack, NJ 07606

Attn To : Michael Levay

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Lab No. : 1610020-107

Client Sample ID. : 107FD-S-S-CUSTODIAL CLOSET NEAR  
CAFE  
DOBBS FERRY SPRINGHURST  
ELEMENTARY

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	< 1.0		1	ug/L	15	10/04/2016 1:25 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-108**  
**Client Sample ID. : 108FD-M-S-OLD BOILER ROOM**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	* 25	*	1	ug/L	15	10/04/2016 1:27 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-109**  
**Client Sample ID. : 109FD-M-S-M-4 ELECTRIC CLOSET**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	9.5		1	ug/L	15	10/04/2016 1:30 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-110**  
**Client Sample ID. : 110FD-M-S-NEW BOILER ROOM**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	5.7		1	ug/L	15	10/04/2016 1:33 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-111**  
**Client Sample ID. : 111FD-M-F-NEAR BOILER RM-LEFT**  
**FOUNTAIN**  
**DOBBS FERRY SPRINGHURST**  
**ELEMENTARY**

Attn To : Michael Levay  
Federal ID :  
Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/04/2016 1:36 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**

280 Huyler Street  
South Hackensack, NJ 07606

Attn To : Michael Levay

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Lab No. : 1610020-112

Client Sample ID. : 112FD-M-F-NEAR BOILER RM-RIGHT  
FOUNTAIN  
DOBBS FERRY SPRINGHURST  
ELEMENTARY

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	< 1.0		1	ug/L	15	10/04/2016 1:51 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-113**  
**Client Sample ID. : 113FD-M-F-ROOM 41**

Attn To : Michael Levay  
Federal ID :

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Collected : 09/24/2016 12:00 AM Point No  
Received : 09/28/2016 12:00 PM Location:  
Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/04/2016 1:54 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

**Lab No. : 1610020-114**  
**Client Sample ID. : 114FD-M-F-ROOM M-6 FOUNTAIN**

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/04/2016 1:57 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.





**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-115  
Client Sample ID. : 115FD-M-F-ROOM M-7 FOUNTAIN

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

<u>Parameter(s)</u>	<u>Results</u>	<u>Qualifier</u>	<u>D.F.</u>	<u>Units</u>	<u>Limit</u>	<u>Analyzed:</u>	<u>Container:</u>
Lead	< 1.0		1	ug/L	15	10/04/2016 2:00 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**  
280 Huyler Street  
South Hackensack, NJ 07606

Lab No. : 1610020-116  
Client Sample ID. : 116FD-M-S-ROOM M-8 FOUNTAIN

Attn To : Michael Levay

**DOBBS FERRY SPRINGHURST  
ELEMENTARY**

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	< 1.0		1	ug/L	15	10/04/2016 2:02 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.

B = Found in Blank

D.F. = Dilution Factor D = Results for Dilution

c = Calibration acceptability criteria exceeded for this analyte. Value estimated

H = Received/analyzed outside of analytical holding time

J = Estimated value - below calibration range

M-, M+ = Matrix Spike recovery below / above control limit

N = Indicates presumptive evidence of compound

P = Duplicate RPD outside of control limit

r = Reporting limit below calibration range. Value estimated.

S = Recovery outside of control limits for this analyte

+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method

Result(s) reported meet(s) Regulatory Limit(s).

Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.

Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



**Sample Information:**

Type : Potable Water  
Origin:

**LABORATORY RESULTS**

Results are only for the samples and analytes requested. Routine  
The lab is not directly responsible for the integrity of the sample before receipt at the lab and is responsible only for the tests requested.

**Omega Environmental Services**

280 Huyler Street  
South Hackensack, NJ 07606

Attn To : Michael Levay

Federal ID :

Collected : 09/24/2016 12:00 AM Point No

Received : 09/28/2016 12:00 PM Location:

Collected By : DE99

Lab No. : 1610020-117

Client Sample ID. : 44FD-M-S-BATHROOM NEAR M-59

DOBBS FERRY SPRINGHURST  
ELEMENTARY

Analytical Method: E200.8 : IOC

Analyst: AG

Parameter(s)	Results	Qualifier	D.F.	Units	Limit	Analyzed:	Container:
Lead	12		1	ug/L	15	10/04/2016 2:05 AM	Container-01 of 01

Qualifiers: E = Value above quantitation range, Value estimated.  
B = Found in Blank  
D.F. = Dilution Factor D = Results for Dilution  
c = Calibration acceptability criteria exceeded for this analyte. Value estimated  
H = Received/analyzed outside of analytical holding time  
J = Estimated value - below calibration range  
M-, M+ = Matrix Spike recovery below / above control limit  
N = Indicates presumptive evidence of compound  
P = Duplicate RPD outside of control limit  
r = Reporting limit below calibration range. Value estimated.  
S = Recovery outside of control limits for this analyte  
+ = NYSDOH ELAP does not offer certification for this analyte / matrix / method  
Result(s) reported meet(s) Regulatory Limit(s).  
Result(s) flagged with \* Exceed Regulatory Limit(s). Limit noted.  
Date Reported : 10/14/2016

Project Manager : Elizabeth Harrison

Test results meet the requirements of NELAC unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.



PACE ANALYTICAL  
 575 Broad Hollow Road  
 Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
 Website: [www.pacelabs.com](http://www.pacelabs.com)

# QC SUMMARY REPORT

WO#: 1610020

14-Oct-16

**Client:** Omega Environmental Services

**Project:** DOBBS FERRY SPRINGHURST ELEMENTA

**BatchID:** R106761

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R	Units: ug/L	Prep Date:	RunNo: 106761
Client ID:	PBW	Batch ID: R106761	TestNo: E200.8	Analysis Date: 10/3/2016	SeqNo: 2368771	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead		< 1.0	1.0			

- Qualifiers:**
- \* Value exceeds Maximum Contaminant Level
  - H Holding times for preparation or analysis exceeded
  - O RSD is greater than RSDlimit
  - S Spike Recovery outside accepted recovery limits
  - D Dilution was required.
  - M Manual Integration used to determine area response
  - P Second column confirmation exceeds
  - W Sample container temperature is out of limit as specified
  - E Value above quantitation range
  - ND Not Detected at the Reporting Limit
  - R RPD outside accepted recovery limits



PACE ANALYTICAL  
 575 Broad Hollow Road  
 Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
 Website: [www.pacelabs.com](http://www.pacelabs.com)

# QC SUMMARY REPORT

WO#: 1610020

14-Oct-16

**Client:** Omega Environmental Services

**Project:** DOBBS FERRY SPRINGHURST ELEMENTA

**BatchID:** R106762

Sample ID	CalBlank	SampType: MBLK	TestCode: 200.8_DW_R	Units: ug/L	Prep Date:	RunNo: 106762
Client ID:	PBW	Batch ID: R106762	TestNo: E200.8	Analysis Date: 10/4/2016	SeqNo: 2368927	
Analyte		Result	PQL	SPK value	SPK Ref Val	%REC LowLimit HighLimit RPD Ref Val %RPD RPDLimit Qual
Lead		< 1.0	1.0			

- Qualifiers:**
- \* Value exceeds Maximum Contaminant Level
  - H Holding times for preparation or analysis exceeded
  - O RSD is greater than RSDlimit
  - S Spike Recovery outside accepted recovery limits
  - D Dilution was required.
  - M Manual Integration used to determine area response
  - P Second column confirmation exceeds
  - W Sample container temperature is out of limit as specified
  - E Value above quantitation range
  - ND Not Detected at the Reporting Limit
  - R RPD outside accepted recovery limits



PACE ANALYTICAL  
 575 Broad Hollow Road  
 Melville, NY 11747  
 TEL: (631) 694-3040 FAX: (631) 420-8436  
 Website: www.pacelabs.com

# Sample Receipt Checklist

Client Name **OES**

Date and Time Received: **9/28/2016 12:00:00 PM**

Work Order Number: **1610020**

RcptNo: **1**

Received by **Erick Johnson**

Completed by: *Mareesa Rubin*

Reviewed by: *[Signature]*

Completed Date: 10/1/2016 2:18:13 PM

Reviewed Date: 10/14/2016 2:05:47 PM

Carrier name: FedEx

- Chain of custody present? Yes  No
- Chain of custody signed when relinquished and received? Yes  No
- Chain of custody agrees with sample labels? Yes  No
- Are matrices correctly identified on Chain of custody? Yes  No
- Is it clear what analyses were requested? Yes  No
- Custody seals intact on sample bottles? Yes  No  Not Present
- Samples in proper container/bottle? Yes  No
- Were correct preservatives used and noted? Yes  No  NA
- Preservative added to bottles:
- Sample Condition? Intact  Broken  Leaking
- Sufficient sample volume for indicated test? Yes  No
- Were container labels complete (ID, Pres, Date)? Yes  No
- All samples received within holding time? Yes  No
- Was an attempt made to cool the samples? Yes  No  NA
- All samples received at a temp. of > 0° C to 6.0° C? Yes  No  NA
- Response when temperature is outside of range:
- Sample Temp. taken and recorded upon receipt? Yes  No  To °
- Water - Were bubbles absent in VOC vials? Yes  No  No Vials
- Water - Was there Chlorine Present? Yes  No  NA
- Water - pH acceptable upon receipt? Yes  No  No Water
- Are Samples considered acceptable? Yes  No
- Custody Seals present? Yes  No
- Airbill or Sticker? Air Bil  Sticker  Not Present
- Airbill No: 7842 0033 9028

Case Number:

SDG:

SAS:

Any No response should be detailed in the comments section below, if applicable.

Client Contacted?  Yes  No  NA Person Contacted:  
 Contact Mode:  Phone:  Fax:  Email:  In Person:

Client Instructions:

Date Contacted: Contacted By:

Regarding:

Comments:

Client didn't include time of collection on COC  
 Sample #100 (client ID- 100FD-S-S-ROOM S-66) is missing.

Sample 45FD was added onto the end of the COC as it was skipped upon original login.

CorrectiveAction:


Sample -100 was found on 10/2/2016 at 4.40 PM.

WorkOrder :  
1610020

## Certifications

---

STATE	CERTIFICATION #
NEW YORK	10478
NEW JERSEY	NY158
CONNECTICUT	PH-0435
MARYLAND	208
MAS S ACHUS E TTS	M-NY026
NE W HAMP S HIRE	2987
RHODE IS LAND	LAO00340
PE NNS YLVANIA	68-00350



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b> Required Client Information:		<b>Section B</b> Required Project Information:		<b>Section C</b> Invoice Information:	
Company:	Omega Environmental	Report To:	Lab@omega-env.com	Attention:	
Address:	280 Huyler Street	Copy To:		Company Name:	Omega Environmental
Email To:	Lab@Omega-env.com	Purchase Order No.:		Address:	
Phone:	201-489-8700	Project Name:	Dobbs Ferry Springhurst Elementary	Pace Quote Reference:	
Requested Due Date/TAT:	5 Day TAT	Project Number:	16-1300	Pace Project Manager:	
				Pace Profile #:	

Page: \_\_\_\_\_ of \_\_\_\_\_

**REGULATORY AGENCY**

NPDES  GROUND WATER  DRINKING WATER

UST  RCRA  OTHER

Site Location: \_\_\_\_\_ STATE: NY

ITEM #	Valid Matrix Codes MATRIX CODE PRINKING WATER DW WASTE WATER WW PRODUCT P SOIL/SOLID SL OIL OL WIPE WP AIR AR OTHER OT TISSUE TS	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives H <sub>2</sub> SO <sub>4</sub> HNO <sub>3</sub> HCl NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> Methanol Other	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
			COMPOSITE START	COMPOSITE END/GRAB						
1	01FD-M-S-Faculty Lounge	DW G	09/24/16			1				
2	02FD-M-S-Room M-37 Nurse's Office	DW G	09/24/16			1				
3	03FD-M-S-Room M-38	DW G	09/24/16			1				
4	04FD-M-S-Room M-39	DW G	09/24/16			1				
5	05FD-M-S-Room M-40	DW G	09/24/16			1				
6	06FD-M-S-Room M-41	DW G	09/24/16			1				
7	07FD-M-S-3rd grade Girl's bath - Left Sink	DW G	09/24/16			1				
8	08FD-M-S-3rd grade Girl's bath - Right Sink	DW G	09/24/16			1				
9	09FD-M-F-Room M-42	DW G	09/24/16			1				
10	10FD-M-S-Room M-42	DW G	09/24/16			1				
11	11FD-M-F-Room M-43	DW G	09/24/16			1				
12	12FD-M-S-Room M-44	DW G	09/24/16			1				

Requested Analysis Filtered (Y/N)

Analysis Test: LEAD IN WATER 200.8

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
D Ekstrand	9/26/16	13:13	<i>[Signature]</i>	9/26/16	13:13	
<i>[Signature]</i>	9/26/16	13:13	<i>[Signature]</i>	9/26/16	13:13	

ADDITIONAL COMMENTS

7842 0033 9028

Temp in °C: \_\_\_\_\_

Received on Ice (Y/N): \_\_\_\_\_

Custody Sealed Cooler (Y/N): \_\_\_\_\_

Samples Intact (Y/N): \_\_\_\_\_

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: D. Ekstrand

SIGNATURE of SAMPLER: *[Signature]*

DATE Signed (MM/DD/YY): 9/26/16

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.





# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: \_\_\_\_\_ of \_\_\_\_\_

## Section A Required Client Information:

Company: Omega Environmental  
 Address: 280 Huyler Street  
 S. Hackensack, NJ 07606  
 Email To: Lab@Omega-env.com  
 Phone: 201-489-8700 Fax: \_\_\_\_\_  
 Requested Due Date/TAT: 5 Day TAT

## Section B Required Project Information:

Report To: Lab@omega-env.com  
 Copy To: \_\_\_\_\_  
 Purchase Order No.: \_\_\_\_\_  
 Project Name: Dobbs Ferry Springhurst Elementary  
 Project Number: 16-1300

## Section C Invoice Information:

Attention: \_\_\_\_\_  
 Company Name: Omega Environmental  
 Address: \_\_\_\_\_  
 NPDES  GROUND WATER  DRINKING WATER  
 UST  RCRA  OTHER \_\_\_\_\_  
 Site Location STATE: NY

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX CODE	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Analysis Test	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
					COMPOSITE START	COMPOSITE END/GRAB							
1	13FD-M-S-Room M-45	DW	G	09/24/16				1	Unpreserved	LEAD IN WATER 200.8			
2	14FD-M-F-Room M-45	DW	G	09/24/16				1	H <sub>2</sub> SO <sub>4</sub>				
3	15FD-M-S-Room M-46	DW	G	09/24/16				1	HNO <sub>3</sub>				
4	16FD-M-F-Room M-46	DW	G	09/24/16				1	HCl				
5	17FD-M-S-Room M-47	DW	G	09/24/16				1	Other				
6	18FD-M-S-Cust. cl by 3rd gd. Ent. (near M-44)	DW	G	09/24/16				1	Methanol				
7	19FD-M-S-Room M-48	DW	G	09/24/16				1	NaOH				
8	20FD-M-F-Room M-46	DW	G	09/24/16				1	Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>				
9	21FD-M-S-Room M-50	DW	G	09/24/16				1	Other				
10	22FD-M-S-Near Room M-53	DW	G	09/24/16				1					
11	23FD-M-S-Gym Girl's bath- Left Sink	DW	G	09/24/16				1					
12	24FD-M-S-Gym Girl's bath -Right Sink	DW	G	09/24/16				1					

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
D. Ekstrand	9/26/16					
<i>[Signature]</i>	9/26/16	13:13	<i>[Signature]</i>	9/26/16	13:13	
<i>[Signature]</i>	9/27/16	16:00				

Temp in °C \_\_\_\_\_

Received on \_\_\_\_\_

Sealed Cooler (Y/N) \_\_\_\_\_

Custody (Y/N) \_\_\_\_\_

Samples Intact (Y/N) \_\_\_\_\_


DATE Signed (MM/DD/YY): 9/26/16

SIGNATURE of SAMPLER: *[Signature]*

PRINT Name of SAMPLER: D. Ekstrand

SAMPLER NAME AND SIGNATURE

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to file charges of 1.5% per month for any invoices not paid within 30 days.



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b> Required Client Information:		<b>Section B</b> Required Project Information:		<b>Section C</b> Invoice Information:	
Company: Omega Environmental	Report To: Lab@omega-env.com	Company Name: Omega Environmental	Attention:	Page: _____ of _____	
Address: 280 Huyler Street	Copy To:	Address:			
S. Hackensack, NJ 07606		Pace Quote Reference:			
Email To: Lab@Omega-env.com	Purchase Order No.:	Pace Project Manager:			
Phone: 201-489-8700 Fax:	Project Name: Dobbs Ferry Springhurst Elementary	Pace Profile #:			
Requested Due Date/TAT: 5 Day TAT	Project Number: 16-1300				

ITEM #	Valid Matrix Codes Required Client Information	MATRIX CODE DW WT P SL OL WP AR OT TS	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP) (see valid codes to left)	MATRIX CODE (see valid codes to left)	DATE	TIME	SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives H <sub>2</sub> SO <sub>4</sub> HNO <sub>3</sub> HCl NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> Methanol Other	Requested Analysis Filtered (Y/N)	Temp In °C	Received on	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)
			COMPOSITE START	COMPOSITE END/GRAB												
1	25FD-M-S-Gym Boy's Bath - Left - Sink	DW	09/24/16	09/24/16	G	DW			1	X						
2	26FD-M-S-Gym Boy's Bath- Right Sink	DW	09/24/16	09/24/16	G	DW			1	X						
3	27FD-M-S-Gm faculty bathroom	DW	09/24/16	09/24/16	G	DW			1	X						
4	28FD-M-S-Gym Custodial closet	DW	09/24/16	09/24/16	G	DW			1	X						
5	29FD-M-S-Café Boy's bathroom	DW	09/24/16	09/24/16	G	DW			1	X						
6	30FD-M-S-Café Girl's bathroom	DW	09/24/16	09/24/16	G	DW			1	X						
7	31FD-M-S-Café near Girl's rm-Bottle Filler	DW	09/24/16	09/24/16	G	DW			1	X						
8	32FD-M-S-Kitchen bathroom	DW	09/24/16	09/24/16	G	DW			1	X						
9	33FD-M-S-Kitchen	DW	09/24/16	09/24/16	G	DW			1	X						
10	34FD-M-S-Kitchen	DW	09/24/16	09/24/16	G	DW			1	X						
11	35FD-M-S-Kitchen	DW	09/24/16	09/24/16	G	DW			1	X						
12	36FD-M-S-Kitchen	DW	09/24/16	09/24/16	G	DW			1	X						

<b>Section D</b> Additional Comments		<b>RELINQUISHED BY / AFFILIATION</b>		<b>DATE</b>		<b>TIME</b>		<b>ACCEPTED BY / AFFILIATION</b>		<b>DATE</b>		<b>TIME</b>		<b>SAMPLE CONDITIONS</b>	
		D. Ekstrand		9/26/16		13:13		[Signature]		9/26/16		13:13		Sealed Cooler (Y/N)	
		[Signature]		9/27/16		10:00		[Signature]		9/27/16		10:00		Received on	
		[Signature]						[Signature]						Temp In °C	
								[Signature]						Custody Sealed Cooler (Y/N)	
								[Signature]						Samples Intact (Y/N)	

SAMPLER NAME AND SIGNATURE: PRINT Name of SAMPLER: D. Ekstrand DATE Signed (MM/DD/YY): 9/26/16  
SIGNATURE of SAMPLER: [Signature]

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b> Required Client Information:		<b>Section B</b> Required Project Information:		<b>Section C</b> Invoice Information:	
Company:	Omega Environmental	Report To:	Lab@omega-env.com	Attention:	
Address:	280 Huyler Street	Copy To:		Company Name:	Omega Environmental
Email To:	S. Hackensack, NJ 07606	Purchase Order No.:		Address:	
Phone:	Lab@Omega-env.com	Project Name:	Dobbs Ferry Springhurst Elementary	Site Location	
Requested Due Date/TAT:	201-489-8700	Project Number:	16-1300	STATE:	NY
	5 Day TAT				

Page: \_\_\_\_\_ of \_\_\_\_\_

ITEM #	Valid Matrix Codes MATRIX CODE DRINKING WATER DW WASTE WATER WW PRODUCT P SOIL/SOLID SL OIL OL WIPE WP AIR AR OTHER OT TISSUE TS	Required Client Information	Matrix Code (see valid codes to left)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives H <sub>2</sub> O <sub>4</sub> HNO <sub>3</sub> HCl NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> Methanol Other	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
				COMPOSITE START	COMPOSITE END/GRAB						
1	37FD-M-S-kitchen		DW G	DATE	TIME	09/24/16	1				
2	38FD-M-S-kitchen		DW G	DATE	TIME	09/24/16	1				
3	39FD-M-S-kitchen		DW G	DATE	TIME	09/24/16	1				
4	40FD-M-S-kitchen		DW G	DATE	TIME	09/24/16	1				
5	41FD-M-S-kitchen		DW G	DATE	TIME	09/24/16	1				
6	42FD-M-S-kitchen		DW G	DATE	TIME	09/24/16	1				
7	43FD-M-S-M-61		DW G	DATE	TIME	09/24/16	1				
8	44FD-M-S-Bathroom near M-59		DW G	DATE	TIME	09/24/16	1				
9	45FD-M-S-Room M-57 Art room - Left Sink		DW G	DATE	TIME	09/24/16	1				
10	45AFD-M-F-Hallway Left of M-1		DW G	DATE	TIME	09/24/16	1				
11	46FD-M-S-Rm M-57 Art room - 2nd left sink		DW G	DATE	TIME	09/24/16	1				
12	47FD-M-S-Rm M-57 Art rm - 2nd right sink		DW G	DATE	TIME	09/24/16	1				

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME
<i>[Signature]</i>	9/26/16	13:13	<i>[Signature]</i>	9/26/16	13:13
ADDITIONAL COMMENTS					

SAMPLER NAME AND SIGNATURE	DATE SIGNED (MM/DD/YYYY)
<i>[Signature]</i>	9/26/16
PRINT Name of SAMPLER: D. Ekstrand	
SIGNATURE of SAMPLER: <i>[Signature]</i>	
Temp in °C	
Received on Ice (Y/N)	
Custody Sealed Cooler (Y/N)	
Samples Intact (Y/N)	

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b> Required Client Information:		<b>Section B</b> Required Project Information:		<b>Section C</b> Invoice Information:	
Company:	Omega Environmental	Report To:	Lab@omega-env.com	Attention:	
Address:	280 Huyler Street	Copy To:		Company Name:	Omega Environmental
	S. Hackensack, NJ 07606	Purchase Order No.:		Address:	
Email To:	Lab@Omega-env.com	Project Name:	Dobbs Ferry Springhurst Elementary	Site Location	STATE: NY
Phone:	201-489-8700	Requested Due Date/TAT:	5 Day TAT	REGULATORY AGENCY	<input type="checkbox"/> NPDES <input type="checkbox"/> GROUND WATER <input checked="" type="checkbox"/> DRINKING WATER <input type="checkbox"/> UST <input type="checkbox"/> RCRA <input type="checkbox"/> OTHER
Requested Due Date/TAT:	5 Day TAT	Project Number:	16-1300	Pace Quote Reference:	
				Pace Project Manager:	
				Pace Profile #:	

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		SAMPLE TEMP AT COLLECTION	# OF CONTAINERS	Preservatives	Requested Analysis Filtered (Y/N)	Temp in °C	Received on	Sealed Cooler (Y/N)	Custody (Y/N)	Samples Intact (Y/N)	
					COMPOSITE START	COMPOSITE END/GRAB										
1	48FD-M-S-Rm M-57 Art rm - right sink	DW	DW	G	09/24/16	09/24/16		1	<input checked="" type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input checked="" type="checkbox"/> HNO <sub>3</sub> <input checked="" type="checkbox"/> HCl <input checked="" type="checkbox"/> NaOH <input checked="" type="checkbox"/> Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> <input checked="" type="checkbox"/> Methanol <input checked="" type="checkbox"/> Other	Y						
2	49FD-M-S-M-3	DW	DW	G	09/24/16	09/24/16		1	<input checked="" type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input checked="" type="checkbox"/> HNO <sub>3</sub> <input checked="" type="checkbox"/> HCl <input checked="" type="checkbox"/> NaOH <input checked="" type="checkbox"/> Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> <input checked="" type="checkbox"/> Methanol <input checked="" type="checkbox"/> Other	Y						
3	50FD-M-S-M-5	DW	DW	G	09/24/16	09/24/16		1	<input checked="" type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input checked="" type="checkbox"/> HNO <sub>3</sub> <input checked="" type="checkbox"/> HCl <input checked="" type="checkbox"/> NaOH <input checked="" type="checkbox"/> Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> <input checked="" type="checkbox"/> Methanol <input checked="" type="checkbox"/> Other	Y						
4	51FD-M-S-Room M-6	DW	DW	G	09/24/16	09/24/16		1	<input checked="" type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input checked="" type="checkbox"/> HNO <sub>3</sub> <input checked="" type="checkbox"/> HCl <input checked="" type="checkbox"/> NaOH <input checked="" type="checkbox"/> Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> <input checked="" type="checkbox"/> Methanol <input checked="" type="checkbox"/> Other	Y						
5	52FD-M-S-Room M-7	DW	DW	G	09/24/16	09/24/16		1	<input checked="" type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input checked="" type="checkbox"/> HNO <sub>3</sub> <input checked="" type="checkbox"/> HCl <input checked="" type="checkbox"/> NaOH <input checked="" type="checkbox"/> Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> <input checked="" type="checkbox"/> Methanol <input checked="" type="checkbox"/> Other	Y						
6	53FD-M-S-Room M-8	DW	DW	G	09/24/16	09/24/16		1	<input checked="" type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input checked="" type="checkbox"/> HNO <sub>3</sub> <input checked="" type="checkbox"/> HCl <input checked="" type="checkbox"/> NaOH <input checked="" type="checkbox"/> Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> <input checked="" type="checkbox"/> Methanol <input checked="" type="checkbox"/> Other	Y						
7	54FD-M-S-Room M-9	DW	DW	G	09/24/16	09/24/16		1	<input checked="" type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input checked="" type="checkbox"/> HNO <sub>3</sub> <input checked="" type="checkbox"/> HCl <input checked="" type="checkbox"/> NaOH <input checked="" type="checkbox"/> Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> <input checked="" type="checkbox"/> Methanol <input checked="" type="checkbox"/> Other	Y						
8	55FD-M-S-Room M-10	DW	DW	G	09/24/16	09/24/16		1	<input checked="" type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input checked="" type="checkbox"/> HNO <sub>3</sub> <input checked="" type="checkbox"/> HCl <input checked="" type="checkbox"/> NaOH <input checked="" type="checkbox"/> Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> <input checked="" type="checkbox"/> Methanol <input checked="" type="checkbox"/> Other	Y						
9	56FD-M-S-Room M-11	DW	DW	G	09/24/16	09/24/16		1	<input checked="" type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input checked="" type="checkbox"/> HNO <sub>3</sub> <input checked="" type="checkbox"/> HCl <input checked="" type="checkbox"/> NaOH <input checked="" type="checkbox"/> Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> <input checked="" type="checkbox"/> Methanol <input checked="" type="checkbox"/> Other	Y						
10	57FD-M-S-Room M-12	DW	DW	G	09/24/16	09/24/16		1	<input checked="" type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input checked="" type="checkbox"/> HNO <sub>3</sub> <input checked="" type="checkbox"/> HCl <input checked="" type="checkbox"/> NaOH <input checked="" type="checkbox"/> Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> <input checked="" type="checkbox"/> Methanol <input checked="" type="checkbox"/> Other	Y						
11	58FD-M-S-Room M-13	DW	DW	G	09/24/16	09/24/16		1	<input checked="" type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input checked="" type="checkbox"/> HNO <sub>3</sub> <input checked="" type="checkbox"/> HCl <input checked="" type="checkbox"/> NaOH <input checked="" type="checkbox"/> Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> <input checked="" type="checkbox"/> Methanol <input checked="" type="checkbox"/> Other	Y						
12	59FD-M-S-Room M-14	DW	DW	G	09/24/16	09/24/16		1	<input checked="" type="checkbox"/> H <sub>2</sub> SO <sub>4</sub> <input checked="" type="checkbox"/> HNO <sub>3</sub> <input checked="" type="checkbox"/> HCl <input checked="" type="checkbox"/> NaOH <input checked="" type="checkbox"/> Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> <input checked="" type="checkbox"/> Methanol <input checked="" type="checkbox"/> Other	Y						

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
<i>[Signature]</i> Ekstrand	9/26/16	13:13	<i>[Signature]</i>	9/26/16	13:13	
<i>[Signature]</i>	9/26/16	11:10	<i>[Signature]</i>	9/26/16	13:13	

SAMPLER NAME AND SIGNATURE  
 PRINT Name of SAMPLER: D. Ekstrand  
 SIGNATURE of SAMPLER: *[Signature]*  
 DATE Signed (MM/DD/YYYY): 9/26/16



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b> Required Client Information: Company: Omega Environmental Address: 280 Huyler Street S. Hackensack, NJ 07606 Email To: Lab@omega-env.com Phone: 201-489-8700 Fax: Requested Due Date/TAT: 5 Day TAT		<b>Section B</b> Required Project Information: Report To: Lab@omega-env.com Copy To: Purchase Order No.: Project Name: Dobbs Ferry Springhurst Elementary Project Number: 16-1300		<b>Section C</b> Invoice Information: Attention: Company Name: Omega Environmental Address: Pace Quote Reference: Pace Project Manager: Pace Profile #:	
REGULATORY AGENCY <input type="checkbox"/> NPDES <input type="checkbox"/> GROUND WATER <input checked="" type="checkbox"/> DRINKING WATER <input type="checkbox"/> UST <input type="checkbox"/> RCRA <input type="checkbox"/> OTHER		Site Location STATE: NY		Page: _____ of _____	

ITEM #	Valid Matrix Codes MATRIX CODE DRINKING WATER DW WASTE WATER WW WASTE WATER PRODUCT P SOILSOLID SL OIL OL WIPE WP AIR AR OTHER OT TISSUE TS	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	MATRIX CODE (see valid codes to left)	# OF CONTAINERS	PRESERVATIVES	Requested Analysis Filtered (Y/N)	Residual Chlorine (Y/N)	Pace Project No./ Lab I.D.
		COMPOSITE START	COMPOSITE END/GRAB							
1	60FD-M-S-Room M-15			G	DW	1	Unpreserved H <sub>2</sub> O <sub>2</sub> HNO <sub>3</sub> HCl NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> Methanol Other			1010020
2	61FD-M-F-Room M-16 – Right Fountain			G	DW	1				
3	62FD-M-F-Room M-16 – Left Fountain			G	DW	1				
4	63FD-M-S-Room M-16 – Right Sink			G	DW	1				
5	64FD-M-S-Room M-16 – Right Sink			G	DW	1				
6	65FD-M-S-1st grade faculty bathroom			G	DW	1				
7	66FD-M-S-Room M-17			G	DW	1				
8	67FD-M-S-Room M-18			G	DW	1				
9	68FD-M-S-Room M-19			G	DW	1				
10	69FD-M-S-Room M-20			G	DW	1				
11	70FD-M-S-1st grade Girl's bath – Left sink			G	DW	1				
12	71FD-M-S-1st grade Girl's bath – 2nd Left Sink			G	DW	1				

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
<i>[Signature]</i> D. Ekstrand	9/26/16	13:13	<i>[Signature]</i>	9/26/16	13:13	Temp in C
<i>[Signature]</i>	9/27/16	10:00	<i>[Signature]</i>	9/27/16	10:00	Received on
						Custody Sealed Cooler (Y/N)
						Samples Intact (Y/N)

SAMPLER NAME AND SIGNATURE  
 PRINT Name of SAMPLER: D. Ekstrand  
 SIGNATURE OF SAMPLER: *[Signature]*  
 DATE Signed (MM/DD/YY): 9/26/16

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b> Required Client Information:		<b>Section B</b> Required Project Information:		<b>Section C</b> Invoice Information:	
Company:	Omega Environmental	Report To:	Lab@omega-env.com	Attention:	
Address:	280 Huyler Street S. Hackensack, NJ 07606	Copy To:		Company Name:	Omega Environmental
Email To:	Lab@Omega-env.com	Purchase Order No.:		Address:	
Phone:	201-489-8700	Project Name:	Dobbs Ferry Springhurst Elementary	Pace Quote Reference:	
Requested Due Date/TAT:	5 Day TAT	Project Number:	16-1300	Pace Project Manager:	
				Pace Profile #:	

Page: \_\_\_\_\_ of \_\_\_\_\_

<b>REGULATORY AGENCY</b>	
<input type="checkbox"/> NPDES	<input type="checkbox"/> GROUND WATER
<input type="checkbox"/> UST	<input type="checkbox"/> RCRA
<input checked="" type="checkbox"/> DRINKING WATER	<input type="checkbox"/> OTHER
Site Location	STATE: NY

ITEM #	Valid Matrix Codes MATRIX CODE DRINKING WATER DW WASTE WATER WTW WASTE WATER PRODUCT WWP SOIL/SOLID SL OIL OL WIPE WP AIR AR OTHER OT TISSUE TS	Matrix Code (see valid codes to left)	COLLECTED		# OF CONTAINERS	Preservatives H <sub>2</sub> SO <sub>4</sub> HNO <sub>3</sub> HCl NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> Methanol Other	Requested Analysis Filtered (Y/N)	Pace Project No./ Lab I.D.
			COMPOSITE START	COMPOSITE END/GRAB				
1	72FD-M-S-1st grd Girl's bath - 2nd Right Sink	DW G	09/24/16	09/24/16	1			1610020
2	73FD-M-S-1st grade Girl's bath-Right Sink	DW G	09/24/16	09/24/16	1			
3	74FD-M-S-1st grade Boy's bath-Left Sink	DW G	09/24/16	09/24/16	1			
4	75FD-M-S-1st grade Boy's bath- 2nd Left Sink	DW G	09/24/16	09/24/16	1			
5	76FD-M-S-1st grade Boy's bath-2nd Right Sink	DW G	09/24/16	09/24/16	1			
6	77FD-M-S-1st grade Boy's bath-Right Sink	DW G	09/24/16	09/24/16	1			
7	78FD-M-S-1st grade custodial closet	DW G	09/24/16	09/24/16	1			
8	79FD-M-S-Faculty bathroom main off area	DW G	09/24/16	09/24/16	1			
9	80FD-M-S-Room M-22	DW G	09/24/16	09/24/16	1			
10	81FD-M-S-Room M-24 mailroom	DW G	09/24/16	09/24/16	1			
11	82FD-G-S-2nd grd Boy's bath-Left Sink	DW G	09/24/16	09/24/16	1			
12	83FD-G-S-2nd grd Boy's bath-Middle Sink	DW G	09/24/16	09/24/16	1			

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
<i>[Signature]</i> Ekstrand	9/26/16		<i>[Signature]</i>	9/26/16		
<i>[Signature]</i>	9/26/16	13:13	<i>[Signature]</i>	9/26/16		
<i>[Signature]</i>	9/27/16	16:00	<i>[Signature]</i>	9/27/16		

Temp in C	Received on	Custody	Sealed Cooler	Samples Intact
<b>SAMPLER NAME AND SIGNATURE</b>				
PRINT Name of SAMPLER: D. Ekstrand				
SIGNATURE of SAMPLER: <i>[Signature]</i>				
DATE Signed (MM/DD/YYYY):				9/26/16

\*Important Note: By signing this form you are accepting Pace's terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b> Required Client Information:		<b>Section B</b> Required Project Information:		<b>Section C</b> Invoice Information:	
Company:	Omega Environmental	Report To:	Lab@omega-env.com	Attention:	
Address:	280 Huyler Street	Copy To:		Company Name:	Omega Environmental
	S. Hackensack, NJ 07606	Purchase Order No.:		Address:	
Email To:	Lab@Omega-env.com	Project Name:	Dobbs Ferry Springhurst Elementary	Site Location	NY
Phone:	201-489-8700	Requested Due Date/TAT:	5 Day TAT	STATE:	

ITEM #	Valid Matrix Codes MATRIX CODE DRINKING WATER DW WASTE WATER WW WASTE WATER PRODUCT WP SOIL/SOLID SL OIL OL WIPE WP AIR AR OTHER OT TISSUE TS	MATRIX CODE (see valid codes to left)	COLLECTED		# OF CONTAINERS	Preservatives HCl HNO <sub>3</sub> H <sub>2</sub> O <sub>4</sub> Unpreserved NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> Methanol Other	Requested Analysis Filtered (Y/N)	Pace Project No. / Lab I.D.
			COMPOSITE START	COMPOSITE END/GRAB				
1	84FD-G-S-2nd grd Boy's bath - Right Sink	DW G	09/24/16	09/24/16	1			1010020
2	85FD-G-S-2nd grd Girl's bath- Left Sink	DW G	09/24/16	09/24/16	1			
3	86FD-G-S-2nd grd Girl's bath- Middle Sink	DW G	09/24/16	09/24/16	1			
4	87FD-G-S-2nd grd Girl's bath- Right Sink	DW G	09/24/16	09/24/16	1			
5	88FD-G-S-Room G-31	DW G	09/24/16	09/24/16	1			
6	89FD-G-S-Room G-32	DW G	09/24/16	09/24/16	1			
7	90FD-G-S-Room G-33	DW G	09/24/16	09/24/16	1			
8	91FD-G-S-G level faculty bathroom	DW G	09/24/16	09/24/16	1			
9	92FD-G-S-Room G-26	DW G	09/24/16	09/24/16	1			
10	93FD-G-S-Room G-28	DW G	09/24/16	09/24/16	1			
11	94FD-G-S-Room G-29	DW G	09/24/16	09/24/16	1			
12	95FD-S-S-5th grade faculty bathroom	DW G	09/24/16	09/24/16	1			

RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
D. Ekstrand	9/26/16	13:13	<i>[Signature]</i>	9/29/16	13:13	
<i>[Signature]</i>	9/27/16	11:10	<i>[Signature]</i>	9/29/16	13:13	

Temp in °C	Received on	Sealed Cooler	Custody	Samples Intact

SAMPLER NAME AND SIGNATURE  
 PRINT Name of SAMPLER: D. Ekstrand  
 SIGNATURE of SAMPLER: *[Signature]*  
 DATE Signed (MM/DD/YYYY): 9/26/16

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.



# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

<b>Section A</b> Required Client Information:		<b>Section B</b> Required Project Information:		<b>Section C</b> Invoice Information:	
Company:	Omega Environmental	Report To:	Lab@omega-env.com	Company Name:	Omega Environmental
Address:	280 Huyler Street	Copy To:		Address:	
Email To:	Lab@Omega-env.com	Purchase Order No.:		Pace Quote Reference:	
Phone:	201-489-8700	Project Name:	Dobbs Ferry Springhurst Elementary	Pace Project Manager:	
Requested Due Date/TAT:	5 Day TAT	Project Number:	16-1300	Pace Profile #:	

Page: \_\_\_\_\_ of \_\_\_\_\_

ITEM #	Valid Matrix Codes Required Client Information	MATRIX CODE (see valid codes to left)	COLLECTED		SAMPLE TYPE (G=GRAB C=COMP)	# OF CONTAINERS	Preservatives	Requested Analysis Filtered (Y/N)	Temp in °C	Received on	Custody Sealed Cooler	Samples Intact
			COMPOSITE START	COMPOSITE END/GRAB								
1	96FD-S-S-5th grd boy's bath- Left Sink	DW	09/24/16	09/24/16	G	1	Unpreserved H <sub>2</sub> SO <sub>4</sub> HNO <sub>3</sub> HCl NaOH Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub> Methanol Other	Y				
2	97FD-S-S-5th grd boy's bath- Right Sink	DW	09/24/16	09/24/16	G	1		Y				
3	98FD-S-S-5th grd girl's bath- Left Sink	DW	09/24/16	09/24/16	G	1		Y				
4	99FD-S-S-5th grd girl's bath- Right Sink	DW	09/24/16	09/24/16	G	1		Y				
5	100FD-S-S-Room S-66	DW	09/24/16	09/24/16	G	1		Y				
6	101FD-S-S-Room S-68	D										
7	102FD-S-S-Room S-69	D										
8	103FD-S-S-Room S-71	D										
9	104FD-S-S-Room S-72	D										
10	105FD-S-S-Room S-73	D										
11	106FD-S-S-Custodians room	D										
12	107FD-S-S-Custodial closet near café	D										

**100 FD missing**

*Handwritten signature: [Signature]*

**DATE SIGNED (MM/DD/YYYY):** 9/26/16

\*Important Note: By signing this form you are accepting Pace's NET 30 day payment terms and agreeing to late charges of 1.5% per month for any invoices not paid within 30 days.





# CHAIN-OF-CUSTODY / Analytical Request Document

The Chain-of-Custody is a LEGAL DOCUMENT. All relevant fields must be completed accurately.

Page: \_\_\_\_\_ of \_\_\_\_\_

## Section A Required Client Information:

Company: Omega Environmental  
 Address: 280 Huyler Street  
 S. Hackensack, NJ 07606  
 Email To: Lab@Omega-env.com  
 Phone: 201-489-8700 Fax:  
 Requested Due Date/TAT: 5 Day TAT

Section B Required Project Information:  
 Report To: Lab@omega-env.com  
 Copy To:  
 Purchase Order No.:  
 Project Name: Dobbs Ferry Springhurst Elementary  
 Project Number: 16-1300

Section C Invoice Information:  
 Attention:  
 Company Name: Omega Environmental  
 Address:  
 Pace Quote Reference:  
 Pace Project Manager:  
 Pace Profile #:

REGULATORY AGENCY  
 NPDES  GROUND WATER  DRINKING WATER  
 UST  RCRA  OTHER

Site Location STATE: NY

ITEM #	Section D Required Client Information	Valid Matrix Codes	MATRIX CODE (see valid codes to left)	SAMPLE TYPE (G=GRAB C=COMP)	COLLECTED		# OF CONTAINERS	Preservatives	Requested Analysis Filtered (Y/N)	Temp in °C	Received on Ice (Y/N)	Custody Sealed Cooler (Y/N)	Samples Intact (Y/N)
					COMPOSITE START	COMPOSITE END/GRAB							
1	108FD-M-S-Old boiler room	DRINKING WATER	DW	G	DATE	TIME	1	Unpreserved	Y				
2	109FD-M-S-M-4 Electric closet	WASTE WATER	DW	G	09/24/16		1	H <sub>2</sub> SO <sub>4</sub>	X				
3	110FD-M-S-New boiler room	WASTE WATER	DW	G	09/24/16		1	NaOH	X				
4	111FD-M-F-Near boiler room - Left Fountain	PRODUCT	DW	G	09/24/16		1	HCl	X				
5	112FD-M-F-Near boiler rm - Right Fountain	SOIL/SOLID	DW	G	09/24/16		1	HNO <sub>3</sub>	X				
6	113FD-M-F-Room 41	OIL	DW	G	09/24/16		1	Other	X				
7	114FD-M-F-Room M-6 Fountain	WIPES	DW	G	09/24/16		1	Methanol	X				
8	115FD-M-F-Room M-7 Fountain	AIR	DW	G	09/24/16		1	Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	X				
9	116FD-M-S-Room M-8 Fountain	OTHER TISSUE	DW	G	09/24/16		1	Other	X				

ADDITIONAL COMMENTS	RELINQUISHED BY / AFFILIATION	DATE	TIME	ACCEPTED BY / AFFILIATION	DATE	TIME	SAMPLE CONDITIONS
	D. Ekstrand	9/26/16					
	Kyle Brown	9/26/16	13:13		9/26/16	13:13	
		9/27/16	16:00				

SAMPLER NAME AND SIGNATURE

PRINT Name of SAMPLER: D. Ekstrand  
 SIGNATURE of SAMPLER: *[Signature]* DATE SIGNED (MM/DD/YY): 9/26/16